

From: Oliver Benson <Oliver.Benson@midsussex.gov.uk>
Sent: 09 April 2025 13:03:11 UTC+01:00
To: "Rachel Richardson" <Rachel.Richardson@midsussex.gov.uk>
Subject: DM/25/0001

Hi Rachel,

As discussed, not sure why these comments didn't go through, but this is what I recorded as submitting in January.

I have reviewed the submitted details and agree with the points made regarding the placement of the air source heat pump. The proposed location on the side of the property, facing a non-habitable area of the neighboring property, along with the 500mm tall retaining wall acting as a barrier, should effectively mitigate any potential noise issues.

However, I have noticed a discrepancy in the submitted details. The noise impact statement mentions the Samsung 8kW Monobloc Air Source Heat Pump, while the submitted details refer to the Vaillant aroTHERM plus. To ensure accuracy and compliance with the planning condition, I kindly request confirmation of the exact model they intend to install.

Any issues, let me know.

All the best,

Ollie

Oliver Benson
Senior Environmental Health Officer
Environmental Protection Team
Tel: 01444 477 059
Email: oliver.benson@midsussex.gov.uk
Website: www.midsussex.gov.uk



"Working together for a better Mid Sussex"