

From: planninginfo@midsussex.gov.uk <planninginfo@midsussex.gov.uk>
Sent: 15 July 2026 08:37:01 UTC+01:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: Mid Sussex DC - Online Register - Consultee Comments for Planning Application
DM/26/1648

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 15/07/2026 8:37 AM from Adam Dracott on behalf of Environmental Protection.

Application Summary

Reference:	DM/26/1648
Address:	55 College Lane Hurstpierpoint Hassocks West Sussex BN6 9AD
Proposal:	Proposed solar panels to be fitted to the south facing roof slope and a ground source heat pump to be fitted in the garden.
Case Officer:	Stefan Galyas

[Click for further information](#)

Comments Details

Comments:	The noise impact from the air source heat pump has not assessed. There is a simplified method under the Microgeneration Certification Scheme in their standards document MCS 020 (a) which can be downloaded at https://mcscertified.com/wp-content/uploads/2025/07/MCS-020-a-Issue-1.0-Final.pdf I recommend that this assessment is completed before the decision is made on this application.
-----------	--

Kind regards