


This is an estimation of the greenfield runoff rates that are used to meet normal best practice criteria in line with Environment Agency guidance “Rainfall runoff management for developments”, SC030219 (2013), the SuDS Manual C753 (CIRIA, 2015) and the non-statutory standards for SuDS (Defra, 2015). This information on greenfield runoff rates may be the basis for setting consents for the drainage of surface water runoff from sites.

Project details

Date	<input type="text" value="30/05/2025"/>
Calculated by	<input type="text"/>
Reference	<input type="text"/>
Model version	<input type="text" value="2.0.1"/>

Location

Site name	<input type="text" value="Network 2 9.4"/>
Site location	<input type="text" value="Burgess Hill"/>



Site easting	<input type="text" value="530949"/>
Site northing	<input type="text" value="121204"/>

Site details

Total site area (ha)	<input type="text" value="1.075"/>	ha
----------------------	------------------------------------	----

Greenfield runoff

Method

Method	IH124	
IH124		
	<u>My value</u>	<u>Map value</u>
SAAR (mm)	<div>816mm</div>	<div><div></div>816</div>
How should SPR be derived?	WRAP soil type	
WRAP soil type	<div>4</div>	<div><div></div>4</div>
SPR	<div>0.47</div>	
QBar (IH124) (l/s)	<div>6.2l/s</div>	

Growth curve factors

	<u>My value</u>	<u>Map value</u>
Hydrological region	<div>7</div>	<div><div></div>7</div>
1 year growth factor	<div>0.85</div>	
2 year growth factor	<div>0.88</div>	
10 year growth factor	<div>1.62</div>	
30 year growth factor	<div>2.3</div>	
100 year growth factor	<div>3.19</div>	
200 year growth factor	<div>3.74</div>	

Results

Method	IH124	
Flow rate 1 year (l/s)	<div>5.3l/s</div>	
Flow rate 2 year (l/s)	<div>5.5l/s</div>	
Flow rate 10 years (l/s)	<div>10.1l/s</div>	
Flow rate 30 years (l/s)	<div>14.3l/s</div>	
Flow rate 100 years (l/s)	<div>19.8l/s</div>	
Flow rate 200 years (l/s)	<div>23.2l/s</div>	

Disclaimer

This report was produced using the Greenfield runoff rate estimation tool (2.0.1) developed by HR Wallingford and available at [uksuds.com](https://www.uksuds.com) (<https://www.uksuds.com/>). The use of this tool is subject to the UK SuDS terms and conditions and licence agreement, which can both be found at [uksuds.com/terms-conditions](https://www.uksuds.com/terms-conditions) (<https://www.uksuds.com/terms-conditions>). The outputs from this tool have been used to estimate Greenfield runoff rates. The use of these results is the responsibility of the users of this tool. No liability will be accepted by HR Wallingford, the Environment Agency, Centre for Ecology and Hydrology, Wallingford Hydrosolutions or any other organisation for the use of these data in the design or operational characteristics of any drainage scheme.