

Igloo Care Ltd (Developer) And EQ Care East
Grinstead Ltd (Operator)
c/o Westbourne Planning Ltd
The Bloomsbury Building
10 New Oxford Street
London
WC1A 2SL

CONTACT: Joanne Fisher
PHONE: 01444 477330
E-MAIL: joanne.fisher@midsussex.gov.uk
REF: DM/24/3051
DATE: 19th February 2026

Dear Sir/Madam

Highfields West Hill East Grinstead West Sussex
Demolition of existing dwelling and the erection of a care home (Class C2) and a separate building with additional care units (Class C2).

I advise that your application DM/24/3051 was **Granted Permission** on **19th February 2026**.

I enclose a copy of the Decision Notice in relation to the above application. If you are acting as an Agent please ensure that a copy is given to the applicant. **Please read the notes accompanying this decision notice carefully.**

Please also be advised that this permission does not constitute an approval under Building Regulations. Before you proceed with your proposal you should ensure that a Building Control application is not required, or has been submitted.

Yours faithfully



Ann Biggs
Assistant Director Planning and Sustainable Economy

Igloo Care Ltd (Developer) And EQ Care East Grinstead Ltd (Operator)
Westbourne Planning Ltd
The Bloomsbury Building
10 New Oxford Street
London
WC1A 2SL

TOWN AND COUNTRY PLANNING ACT 1990
TOWN AND COUNTRY PLANNING (DEVELOPMENT MANAGEMENT PROCEDURE)
(ENGLAND) ORDER 2015

PERMISSION

REFERENCE: DM/24/3051

DESCRIPTION: DEMOLITION OF EXISTING DWELLING AND THE ERECTION OF A CARE HOME (CLASS C2) AND A SEPARATE BUILDING WITH ADDITIONAL CARE UNITS (CLASS C2).

LOCATION: HIGHFIELDS, WEST HILL, EAST GRINSTEAD, WEST SUSSEX

DECISION DATE: 19 FEB 2026

CASE OFFICER: JOANNE FISHER - JOANNE.FISHER@MIDSUSSEX.GOV.UK

The Council hereby notify you that they **GRANT** planning permission for the above development to be carried out in accordance with the submitted application and plans and subject to compliance with the following conditions:-

Conditions

1. The development hereby permitted shall be begun before the expiration of 3 years from the date of this permission.

Reason: To comply with Section 91 of the Town and Country Planning Act 1990.

Approved Plans

2. The development hereby permitted shall be carried out in accordance with the plans listed below under the heading "Plans Referred to in Consideration of this Application".

Reason: For the avoidance of doubt and in the interest of proper planning.

Pre commencement

3. Prior to the commencement of the development, a Construction Environmental Management Plan (CEMP) shall be submitted to and approved in writing by the Local Planning Authority. Thereafter the approved Plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters,
- o the anticipated number, frequency and types of vehicles used during construction,
 - o the details of any retention and surfacing of the temporary access road,
 - o the method of access and routing of vehicles during construction,
 - o the parking of vehicles by site operatives and visitors,
 - o the loading and unloading of plant, materials and waste,
 - o the storage of plant and materials used in construction of the development,
 - o the erection and maintenance of security hoarding,
 - o the provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulation Orders),
 - o details of public engagement both prior to and during construction works,
 - o details of measures to control noise or vibration affecting nearby residents; artificial illumination,
 - o dust control measures,
 - o measures to deal with surface water run-off from the site during construction,
 - o pollution incident control and site contact details in case of complaints.

Reason: In the interests of highway safety and the amenities of the area and to accord with Policies DP21 and DP26 of the Mid Sussex District Plan 2014 - 2031.

4. Prior to the commencement of any part of the development, a Construction Environmental Management Plan (CEMP: Biodiversity) shall be submitted to and approved in writing by the local planning authority, in line with the Relevant Method Statements and Working Practices (Leigh Ecology Ltd, June 2025) and the Badger Activity and Mitigation Proposals (Leigh Ecology Ltd, June 2025).

The CEMP (Biodiversity) shall include the following:

- Risk assessment of potentially damaging construction activities.
- Identification of "biodiversity protection zones".
- Practical measures (both physical measures and sensitive working practices) to avoid or reduce impacts during construction (may be provided as a set of method statements).
- The location and timing of sensitive works to avoid harm to biodiversity features.
- The times during construction when specialist ecologists need to be present on site to oversee works.
- Responsible persons and lines of communication.
- The role and responsibilities on site of an ecological clerk of works (ECoW) or similarly competent person.
- Use of protective fences, exclusion barriers and warning signs.

The approved CEMP shall be adhered to and implemented throughout the construction period strictly in accordance with the approved details.

Reason: To conserve protected and Priority species and allow the LPA to discharge its duties under the Conservation of Habitats and Species Regulations 2017 (as amended), the Wildlife & Countryside Act 1981 (as amended) and s40 of the NERC Act 2006 (as amended).

5. Other than works to construct the new vehicular access from West Hill, no other part of the development shall commence until such time as the new vehicular access serving the development from West Hill has been constructed in accordance with the approved plans, including the agreed bank works to achieve the required visibility splays. This also includes signage and some physical feature on the existing access road to restrict vehicular access to the development, so there is no intensification of the existing substandard access.

Reason: In the interests of road safety and to accord with Policies DP21 and DP26 of the Mid Sussex District Plan 2014 - 2031.

6. Prior to the commencement of development, construction drawings of the surface water drainage network, associated sustainable drainage components and flow control mechanisms and a construction method statement shall be submitted and agreed in writing by the Local Planning Authority. The scheme shall then be constructed as per the agreed drawings, method statement, FRA and Drawings and remain in perpetuity for the lifetime of the development unless agreed in writing by the Local Planning Authority. No alteration to the agreed drainage scheme shall occur without prior written approval from the Local Planning Authority.

Reason: To ensure that the development achieves a high standard of sustainability and to comply with NPPF and to accord with Policy DP38 of the Mid Sussex District Plan 2014 - 2031.

7. Prior to the commencement of development approved by this planning permission (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site, including the identification and removal of asbestos containing materials, shall each be submitted to and approved, in writing, by the Local Planning Authority:

a) A site investigation, based on the phase 1 geo-environmental assessment report undertaken by Brownfield Solutions Ltd, dated December 2024, ref: NA/C5969/13737, to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site;

and, unless otherwise agreed in writing by the LPA,

b) Based on the site investigation results and the detailed risk assessment (a) an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.

Reason: To ensure that the risks from land contamination to the future users of the land are minimised, and to ensure that the development can be carried out safely without unacceptable risks to workers, neighbours and other offsite receptors and to accord with Policy DP1 of the Mid Sussex District Plan 2014 - 2031.

8. Prior to the laying of any foundations to development, details showing the proposed location of one fire hydrant or stored water supply (in accordance with the West Sussex Fire and Rescue Guidance Notes) shall be submitted to and approved in writing by the Local Planning Authority in consultation with West Sussex County Council's Fire and Rescue Service.

Reason: In the interests of amenity and in accordance with Policy DP20 Mid Sussex District Plan 2014 - 2031 and the Fire and Rescue Service Act 2004.

9. Prior to the commencement of any works, detailed plans showing the retaining walls to the front entrance including the materials to be used in its construction shall be submitted to and approved in writing to the Local Planning Authority. The works shall be carried out in accordance with the approved details thereafter.

Reason: To protect the character of the area and to accord with Policy DP26 of the Mid Sussex District Plan and Policy EG3 of the Neighbourhood Plan.

10. No development above ground slab level shall be carried out unless and until samples of materials and finishes to be used for external walls and roofs of the proposed development have been submitted to and approved by the Local Planning Authority. The works shall be carried out in accordance with the approved details.

Reason: To enable the Local Planning Authority to control the development in detail in the interests of amenity by endeavouring to achieve a building of visual quality and to accord with Policy DP26 of the Mid Sussex District Plan 2014 - 2031 and Policy EG5 of the Neighbourhood Plan.

11. Prior to any works above slab level, a Biodiversity Enhancement Strategy for protected, Priority and threatened species, prepared by a suitably qualified ecologist, shall be submitted to and approved in writing by the Local Planning Authority.

The content of the Biodiversity Enhancement Strategy shall include the following:

- purpose and conservation objectives for the proposed enhancement measures;
- detailed designs or product descriptions to achieve stated objectives;
- locations of proposed enhancement measures by appropriate maps and plans (where relevant);
- persons responsible for implementing the enhancement measures; and
- details of initial aftercare and long-term maintenance (where relevant).

The works shall be implemented in accordance with the approved details shall be retained in that manner thereafter.

Reason: To enhance protected, Priority and threatened species and allow the LPA to discharge its duties under paragraph 187d of NPPF 2024 and s40 of the NERC Act 2006 (as amended) and to accord with Policy DP38 of the Mid Sussex District Plan 2014 - 2031.

12. No development above ground slab level shall take place until there has been submitted to, and approved in writing by, the Local Planning Authority full details of a hard and soft landscaping scheme and these works shall be carried out as approved. The works shall be carried out prior to the occupation of any part of the development or in accordance with the programme agreed by the Local Planning Authority. Any trees or plants which, within a period of five years from the completion of development, die, are removed or become seriously damaged or diseased, shall be replaced in the next planting season with others of similar size and species, unless the Local Planning Authority gives written consent to any variation.

Reason: In the interests of visual amenity and of the environment of the development and to accord with Policy DP26 of the Mid Sussex District Plan 2014 - 2031.

13. No development above ground slab level shall be carried out until details of proposed screen walls/fences and/or hedges including those serving the terrace and balcony areas have been submitted to and approved by the Local Planning Authority and no dwellings

shall be occupied until such screen walls/fences or hedges associated with them have been erected or planted.

Reason: In order to protect the appearance of the area and to accord with and Policy DP26 of the Mid Sussex District Plan 2014 - 2031 and Policy EG3 of the Neighbourhood Plan.

14. No development shall be carried out above ground slab level unless and until there has been submitted to and approved in writing by the Local Planning Authority full details of the PV scheme. The scheme to be implemented as approved.

Reason: In order to protect the appearance of the area and to accord with and Policy DP26 of the Mid Sussex District Plan 2014 - 2031 and Policy EG3 of the Neighbourhood Plan.

Construction Phase

15. Works of construction, including the use of plant and machinery, necessary for implementation of this consent shall be limited to the following times:

Monday to Friday 08:00 - 18:00 hours

Saturday 09:00 - 13:00 hours

Sundays and Bank/Public Holidays: No work permitted.

Reason: To protect the amenity of local residents and to accord with Policy DP29 of the Mid Sussex District Plan 2014 - 2031.

16. Deliveries or collection of plant, equipment, or materials for use during the construction phases shall be limited to the following times:

Monday to Friday: 08:00 - 18:00 hrs

Saturday: 09:00 - 13:00 hrs

Sunday & Public/Bank holidays: None permitted.

Reason: To protect the amenity of local residents and to accord with Policy DP29 of the Mid Sussex District Plan 2014 - 2031.

17. If during construction, contamination not previously identified is found to be present at the site then no further development (unless otherwise agreed in writing by the LPA), shall be carried out until a method statement identifying, assessing the risk and proposing remediation measures, together with a programme, shall be submitted to and approved in writing by the LPA. The remediation measures shall be carried out as approved and in accordance with the approved programme. If no unexpected contamination is encountered during development works, on completion of works and prior to occupation a letter confirming this should be submitted to the LPA. If unexpected contamination is encountered during development works, on completion of works and prior to occupation, the agreed information, results of investigation and details of any remediation undertaken will be produced to the satisfaction of and approved in writing by the Local Planning Authority.

Reason: To ensure that the risks from land contamination to the future users of the land are minimised, and to ensure that the development can be carried out safely without unacceptable risks to workers, neighbours and other offsite receptors and to accord with Policy DP1 of the Mid Sussex District Plan 2014 - 2031.

18. The works shall be carried out in accordance with the Tree Survey Preliminary Arboricultural Impact Assessment and Method Statement (Rev 02) dated 20th October 2025.

Reason: To ensure the retention and maintenance of trees and vegetation which is an important feature of the area and to accord with Policy DP37 of the Mid Sussex District Plan 2014 - 2031.

19. The works shall be carried out in accordance with the details set out in the Sustainability Statement (version 1.0 dated 5th December 2024).

Reason: To achieve a high quality and sustainable development and to accord with sustainability policies set out in policies DP21 and DP39 of the Mid Sussex District Plan and the requirements of the NPPF.

Pre-occupation conditions

20. The development hereby approved shall not be first occupied until details of the maintenance and management of the sustainable drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The drainage scheme shall be implemented prior to the first occupation of the development hereby approved and thereafter managed and maintained in accordance with the approved details in perpetuity. The Local Planning Authority shall be granted access to inspect the sustainable drainage scheme for the lifetime of the development. The details of the scheme to be submitted for approval shall include:

- I. a timetable for its implementation,
- II. details of SuDS features and connecting drainage structures and maintenance requirement for each aspect
- III. a management and maintenance plan for the lifetime of the development which shall include the arrangements for adoption by any public body or statutory undertaker, or any other arrangements to secure the operation of the sustainable drainage scheme throughout its lifetime.

Reason: To ensure that the development achieves a high standard of sustainability and ensure the flood risk is adequately addressed for each new dwelling and not increased in accordance with NPPF and Policy DP41 of the Mid Sussex District Plan 2014-2031.

21. Upon completion of the surface water drainage system, including any SuDS features, and prior to the first occupation of the development; a survey and report from an independent surveyor shall be submitted to and approved in writing by the Local Planning Authority. The survey and report shall demonstrate that the surface water drainage system has been constructed in accordance with the details approved pursuant to condition 6. Where necessary, details of corrective works to be carried out along with a timetable for their completion, shall be included for approval in writing by the Local Planning Authority. Any corrective works required shall be carried out in accordance with the approved timetable and subsequently re-surveyed with the findings submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the flood risk is adequately addressed, not increased and users remain safe for the lifetime of the development in accordance with NPPF and Policy DP41 of the Mid Sussex District Plan 2014-2031.

22. Prior to occupation, a "lighting design strategy for biodiversity" in accordance with Guidance Note 08/23 (Institute of Lighting Professionals) shall be submitted to and approved in writing by the local planning authority. The strategy shall:

- identify those areas/features on site that are particularly sensitive to bats and that are likely to cause disturbance in or around their breeding sites and resting places or along important routes used to access key areas of their territory, for example, for foraging; and
- show how and where external lighting will be installed (through provision of appropriate technical specifications) so that it can be clearly demonstrated that areas to be lit will not disturb or prevent the above species using their territory or having access to their breeding sites and resting places.

All external lighting shall be installed in accordance with the specifications and locations set out in the scheme and maintained thereafter in accordance with the scheme. Under no circumstances should any other external lighting be installed without prior consent from the Local Planning Authority.

Reason: To allow the LPA to discharge its duties under the Conservation of Habitats and Species Regulations 2017 (as amended), the Wildlife & Countryside Act 1981 (as amended) and s40 of the NERC Act 2006 (as amended) and to accord with Policy DP38 of the Mid Sussex District Plan 2014 - 2031.

23. No part of the development shall be first occupied until the vehicle parking and turning spaces have been constructed in accordance with the approved plan. These spaces shall thereafter be retained for their designated use.

Reason: To provide adequate on-site car parking and turning space for the development and to accord with Policy DP21 of the Mid Sussex District Plan 2014-2031.

24. No part of the development shall be first occupied until such time as a Travel Plan Statement has been submitted to and approved in writing by the Local Planning Authority. The Travel Plan Statement shall be completed in accordance with the latest guidance and good practice documentation as published by the Department for Transport or as advised by the Highway Authority.

Reason: To encourage and promote sustainable transport and to accord with Policy DP221 of the Mid Sussex District Plan 2014-2031.

25. No part of the development shall be first occupied until covered and secure cycle parking spaces serving the development have been provided in accordance with the approved plans.

Reason: To provide alternative travel options to the use of the car in accordance with current sustainable transport policies and to accord with Policy DP21 of the Mid Sussex District Plan 2014 - 2031.

26. Prior to the opening of any part of the development hereby permitted, the details of a scheme of mitigation measures to improve air quality relating to the development shall be submitted and approved in writing by the Local Planning Authority. The scheme shall be in accordance with, and to a value derived in accordance with, the Air quality and emissions mitigation guidance for Sussex which is current at the time of the application. All works which form part of the approved scheme shall be completed before any part of the development is occupied and shall thereafter be maintained in accordance with the approved details.

Reason: To protect the amenity of neighbouring residents and to accord with Policy DP29 of Mid Sussex District Plan.

27. The development hereby permitted shall not be occupied/brought into use until there has been submitted to and approved in writing by the Local Planning Authority a verification plan by a competent person showing that the remediation scheme required and approved has been implemented fully and in accordance with the approved details (unless varied with the written agreement of the LPA in advance of implementation). Any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action shall be identified within the report, and thereafter maintained.

Reason: To ensure that the risks from land contamination to the future users of the land are minimised, and to ensure that the development can be carried out safely without unacceptable risks to workers, neighbours and other offsite receptors and to accord with Policy DP1 of the Mid Sussex District Plan 2014 - 2031.

28. Prior to the first occupation of the new build Care Home, the developer will at their own expense install the fire hydrant in the approved location to BS 750 standards or stored water supply and arrange for their connection to a water supply which is appropriate in terms of both pressure and volume for the purposes of firefighting.

Prior to the first occupation of the new build Care Home, they will notify the West Sussex County Council's Fire and Rescue Service that the fire hydrant(s) have been installed and are operational, to ensure that the Fire and Rescue Service are aware that the hydrant(s) is now a usable asset in the event of a fire.

The fire hydrant shall thereafter be maintained as part of the development by the water undertaker at the expense of the Fire and Rescue Service if adopted as part of the public mains supply (Fire Services Act 2004) or by the owner / occupier if the installation is retained as a private network.

Reason: In the interests of amenity and in accordance with Policy DP20 Mid Sussex District Plan 2014 - 2031 and the Fire & Rescue Service Act 2004.

Post occupation / management conditions

29. There shall be no deliveries or collections of commercial goods or waste outside the following hours:

Mon to Fri 07:00 to 21:00 hours

Sat 08:00 to 18:00 hours

Sun and Public Holidays: none permitted.

Reasons: To protect the amenity of neighbouring residents and to accord with Policy DP29 of Mid Sussex District Plan.

30. Unless otherwise agreed in writing, noise associated with fixed plant and machinery located at the development shall be controlled such that the noise Rating Level shall not exceed the background noise level LA90, (T) at any premises used for residential purposes surrounding the site, when assessed in accordance with BS 4142:2014+A1(2019).

Reason: To protect the amenity of neighbouring residents and to accord with Policy DP29 of Mid Sussex District Plan.

Biodiversity Net Gain

1. This permission is considered to be one which **will require the approval of a biodiversity gain plan before development is begun** (which includes demolition) because none of the statutory exemptions or transitional arrangements are considered to apply.

Please see the information contained within the notes to applicants/agents set out below.

Informatives

1. Your attention is drawn to the requirements of the Environmental Protection Act 1990 with regard to your duty of care not to cause the neighbours of the site a nuisance. Accordingly, you are requested that:
 - Measures shall be implemented to prevent dust generated on site from crossing the site boundary during the demolition/construction phase of the development.
 - No burning of materials shall take place on site at any time.If you require any further information on these issues, please contact Environmental Protection on 01444 477292.
2. The applicant is required to obtain all appropriate consents from West Sussex County Council, as Highway Authority, to cover the off-site highway works. The applicant is requested to contact The Implementation Team Leader (01243 642105) to commence this process. The applicant is advised that it is an offence to undertake any works within the highway prior to the agreement being in place.
3. The applicant is advised of the requirement to enter into early discussions with and obtain the necessary licenses from the Highway Authority to cover any temporary construction related works that will obstruct or affect the normal operation of the public highway prior to any works commencing. These temporary works may include the placing of skips or other materials within the highway, the temporary closure of on-street parking bays, the imposition of temporary parking restrictions requiring a Temporary Traffic Regulation Order, the erection of hoarding or scaffolding within the limits of the highway, the provision of cranes over-sailing the highway.
4. The applicant is advised that the erection of temporary directional signage should be agreed with the Local Traffic Engineer prior to any signage being installed. The applicant should be aware that a charge will be applied for this service
5. In relation to the drainage conditions, at discharge of condition stage we will need to see details as to how maintenance will be managed within the final storage tank design, including the interconnecting pipes currently proposed. Consideration will need to be given to silt management to ensure the system is resilient to build up and can easily be maintained in general (as there is only access to one chamber in this type of design). We recommend consulting the CIRIA SuDS manual for further guidance on requirements.
6. In order to protect and safeguard the existing water supply apparatus, Southern Water requests formal notification of any proposed demolition works prior to such works being undertaken.
For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)
Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk
7. Southern Water requires a formal application for a connection to the public sewer to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service:
<https://developerservices.southernwater.co.uk> and please read our New Connections Charging Arrangements documents which are available on our website via the following link:
<https://www.southernwater.co.uk/developing-building/connection-charging-arrangements>

8. In relation to condition 26, order to ensure approval, we strongly recommend that the above scheme is agreed in advance with the Council's Air Quality Officer.
9. The proposed development will require formal address allocation. You are advised to contact the Council's Street Naming and Numbering Officer before work starts on site. Details of fees and developers advice can be found at www.midsussex.gov.uk/streetnaming or by phone on 01444 477175.
10. You are advised that this planning permission requires compliance with a planning condition(s) before development commences. You are therefore advised to contact the case officer as soon as possible, or you can obtain further information from: <https://www.gov.uk/guidance/use-of-planning-conditions#discharging-and-modifying-conditions> (Fee of £298 will be payable per request). If you carry out works prior to a pre-development condition being discharged then a lawful start will not have been made, and you will be liable to enforcement action.
11. In accordance with Article 35 of the Town and Country Planning (Development Management Procedure) (England) Order 2015, the Local Planning Authority has acted positively and proactively in determining this application by identifying matters of concern within the application (as originally submitted) and negotiating, with the Applicant, acceptable amendments to the proposal to address those concerns. As a result, the Local Planning Authority has been able to grant planning permission for an acceptable proposal, in accordance with the presumption in favour of sustainable development, as set out within the National Planning Policy Framework.
12. In respect of condition 12, it is expected that suitable additional tree planting also be provided along the south-eastern boundary with Dexter Drive.

Human Rights Implications

The planning application has been considered in light of statute and case law and any interference with an individual's human rights is considered to be proportionate to the aims sought to be realised.

Plans Referred to in Consideration of this Application

The following plans and documents were considered when making the above decision:

Plan Type	Reference	Version	Submitted Date
Location Plan	AP24022-D00		13.12.2024
Site Plan	AP24022-D01	J	07.08.2025
Proposed Floor Plans	AP24022-D02	E	07.08.2025
Proposed Elevations	AP24022-D03	A	13.12.2024
Proposed Floor and Elevations Plan	AP24022-D05		13.12.2024
Access Plan	C24195-ATP-DR-TP-001	P04	30.06.2025
Other	11089-802	P1	30.06.2025
Block Plan	AP24022-D06	A	30.06.2025



Ann Biggs
Assistant Director Planning and Sustainable Economy

PEFULZ

APPEALS TO THE SECRETARY OF STATE

Notes for Applicants

If you are aggrieved by the decision of your Local Planning Authority to refuse permission for the proposed development or to grant it subject to conditions, then you can appeal to the Secretary of State under Section 78 of the Town and Country Planning Act 1990.

If you want to appeal against your local planning authority's decision then you must do so within 6 months (8 weeks in the case of advertisements, 12 weeks in the case of householder or minor commercial development) of the date of this notice *(see exceptions below)

Appeals can be made online at: <https://www.gov.uk/planning-inspectorate>. If you are unable to access the online appeal form, please contact the Planning Inspectorate to obtain a paper copy of the appeal form on Tel: 0303 444 5000.

The Secretary of State can allow a longer period for giving notice of an appeal but will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal.

The Secretary of State need not consider an appeal if it seems to the Secretary of State that the local planning authority could not have granted permission for the proposed development or could not have granted it without the conditions they imposed, having regard to the statutory requirements, to the provisions of any development order and to any directions given under a development order.

If you intend to submit an appeal that you would like examined by inquiry then you must notify the Local Planning Authority and Planning Inspectorate (inquiryappeals@planninginspectorate.gov.uk) at least 10 days before submitting the appeal. Further details are on GOV.uk.

- * If this decision relates to the same or substantially the same land and development as is already the subject of an enforcement notice, if you want to appeal against your local planning authority's decision on your application, then you must do so within 28 days of the date of this notice.*
- * If an enforcement notice is served relating to the same or substantially the same land and development as in your application and if you want to appeal against your local planning authority's decision on your application, then you must do so within: 28 days of the date of service of the enforcement notice, or within 6 months (12 weeks in the case of a householder appeal) of the date of this notice, whichever period expires earlier.*

Biodiversity Net Gain

The effect of paragraph 13 of Schedule 7A to the Town and Country Planning Act 1990 is that planning permission granted for the development of land in England is deemed to have been granted subject to the condition "(the biodiversity gain condition)" that development may not begin unless:

- (a) a Biodiversity Gain Plan has been submitted to the planning authority, and
- (b) the planning authority has approved the plan.

The planning authority, for the purposes of determining whether to approve a Biodiversity Gain Plan if one is required in respect of this permission would be Mid Sussex District Council.

There are statutory exemptions and transitional arrangements which mean that the biodiversity gain condition does not always apply.

Statutory exemptions and transitional arrangements in respect of the biodiversity gain condition that apply in this instance

Development of a biodiversity gain site, meaning development which is undertaken solely or mainly for the purpose of fulfilling, in whole or in part, the Biodiversity Gain Planning condition which applies in relation to another development, (no account is to be taken of any facility for the public to access or to use the site for educational or recreational purposes, if that access or use is permitted without the payment of a fee).

Irreplaceable habitat

If the onsite habitat includes irreplaceable habitat (within the meaning of the Biodiversity Gain Requirements (Irreplaceable Habitat) Regulations 2024) there are additional requirements for the content and approval of Biodiversity Gain Plans.

The Biodiversity Gain Plan must include, in addition to information about steps taken or to be taken to minimise any adverse effect of the development on the habitat, information on arrangements for compensation for any impact the development has on the biodiversity of the irreplaceable habitat.

The planning authority can only approve a Biodiversity Gain Plan if satisfied that the adverse effect of the development on the biodiversity of the irreplaceable habitat is minimised and appropriate arrangements have been made for the purpose of compensating for any impact which do not include the use of biodiversity credits.

The effect of section 73D of the Town and Country Planning Act 1990

If planning permission is granted on an application made under section 73 of the Town and Country Planning Act 1990 (application to develop land without compliance with conditions previously attached) and a Biodiversity Gain Plan was approved in relation to the previous planning permission ("the earlier Biodiversity Gain Plan") there are circumstances when the earlier Biodiversity Gain Plan is regarded as approved for the purpose of discharging the biodiversity gain condition subject to which the section 73 planning permission is granted.

Those circumstances are that the conditions subject to which the section 73 permission is granted:

- i) do not affect the post-development value of the onsite habitat as specified in the earlier Biodiversity Gain Plan, and
- ii) in the case of planning permission for a development where all or any part of the onsite habitat is irreplaceable habitat the conditions do not change the effect of the development on the biodiversity of that onsite habitat (including any arrangements made to compensate for any such effect) as specified in the earlier Biodiversity Gain Plan.

The effect of Paragraph 19 of Schedule 7A to the Town and Country Planning Act 1990

If the permission which has been granted has the effect of requiring or permitting the development to proceed in phases, the modifications in respect of the biodiversity gain condition which are set out in Part 2 of the Biodiversity Gain (Town and Country Planning) (Modifications and Amendments) (England) Regulations 2024 apply.

In summary: Biodiversity gain plans are required to be submitted to, and approved by, the planning authority before development may be begun (the overall plan), and before each phase of development may be begun (phase plans).

Purchase Notices

If either the Local Planning Authority or Secretary of States refuses permission to develop land or grants it subject to conditions, the owner may claim that he can neither put the land to a reasonably beneficial use in its existing state nor render the land capable of a reasonably beneficial use by the carrying out of any development which has been or would be permitted.

In these circumstances the owner may serve a purchase notice on the District Council. This notice will require the Council to purchase their interest in the land in accordance with the provisions of Part VI of the Town and Country Planning Act 1990.