

From: planninginfo@midsussex.gov.uk <planninginfo@midsussex.gov.uk>
Sent: 15 May 2026 19:54:11 UTC+01:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: Mid Sussex DC - Online Register - Consultee Comments for Planning Application
DM/25/1384

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 15/05/2026 7:54 PM from Mr Nick Bennett on behalf of Environmental Protection.

Application Summary

Reference:	DM/25/1384
Address:	Mill Studio Old Hollow Copthorne Crawley West Sussex RH10 4TB
Proposal:	Retention of heat pump (Amended Plans and info rcvd 22.04.2026)
Case Officer:	Tracie Axford

[Click for further information](#)

Comments Details

Comments:	The submitted acoustic report demonstrates that the noise from the ASHP will not cause significant adverse impact, as long as the specified acoustic enclosure is correctly fitted. On this basis EP has no objection to the development providing that the appropriate acoustic enclosure is installed.
-----------	--

Kind regards