

**From:** drainage <drainage@midsussex.gov.uk>  
**Sent:** 27 June 2025 14:19:14 UTC+01:00  
**To:** "Anna Tidey" <anna.tidey@midsussex.gov.uk>  
**Cc:** "drainage" <drainage@midsussex.gov.uk>  
**Subject:** 2025.06.27 Re: DM/25/1024 - DOC - Providence Farm Colwood Lane Warninglid  
Haywards Heath West Sussex RH17 5UE

Dear Anna,

Please find below comments for DM/25/1024 – Condition 3.

(We are assuming you will discharge Condition 2 as this relates to approved plans.)

The Flood Risk and Drainage team have reviewed the information submitted and have the following comments regarding Condition 3:

We can confirm that, based on the information provided the condition can be discharged. This is due to all newly introduced hardstanding areas will be permeable in nature.

Best Wishes

**Flood Risk and Drainage Team**  
**Estate Services and Building Control**  
**Mid Sussex District Council**  
[drainage@midsussex.gov.uk](mailto:drainage@midsussex.gov.uk)