

From: drainage <drainage@midsussex.gov.uk>
Sent: 08 April 2026 14:40:25 UTC+01:00
To: "Hamish Evans" <Hamish.Evans@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2026.04.08 Re: DM/26/0374 - Birch Trees Farm, Cuckfield Road, Ansty, Haywards Heath

Dear Hamish,

The Flood Risk and Drainage Team have reviewed the updated information and have the following comments:

Onward connectivity must not include routing flows overland.

Upon receipt of this additional information, we will be able to comment further. Receipt of the requested additional information does not mean further information will not be requested.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk