

From: Emily Rowe <Emily.rowe@harrisirwin.com>
Sent: 26 February 2026 16:30:01 UTC+00:00
To: "Andy Watt" <Andy.Watt@midsussex.gov.uk>
Cc: "Richard Woodcock" <richard.woodcock@harrisirwin.com>; "Ben Garlick" <Ben.Garlick@harrisirwin.com>
Subject: RE: Planning consultation - DM/26/0003 3-25 Bolnore Road, Haywards Heath, RH16 4AB
Attachments: NARS 26665 New Care Home Bolnore Road.pdf

Hi Andy,

The contractor has confirmed that they can install the hydrant in the location requested by the local fire authority (as shown in the attachment) for Condition 15 of the above application. If you require anything further, please get in touch.

Kind regards,

Emily Rowe BA(Hons), MArch

Part 2 Architectural Assistant



D: 01748 486037

O: 01748 825675 (ext 1027)

Emily.rowe@harrisirwin.com

www.harrisirwin.com

My work days are Tuesday – Friday, for urgent enquires outside of these hours please contact the office.

Our new office address is Harris Irwin Architects, Lilley House, Olliver, Richmond, North Yorkshire, DL10 5HX. Our telephone number, email and website remain unchanged.



This email and all the attachments it may contain are confidential and intended solely for the use of the individual to whom it is addressed. Any views or opinions presented are solely those of the author and do not necessarily represent those of Harris Irwin Associates Limited. If you are not the intended recipient, be advised that you have received this email in error and that any use, dissemination, printing, forwarding or copying of this email is strictly prohibited. Please contact the sender if you have received this email in error. Registered in England and Wales No. 5332633.



Please consider your environmental responsibility before printing this email

From: Andy Watt <Andy.Watt@midsussex.gov.uk>
Sent: 09 January 2026 12:12
To: Richard Woodcock <richard.woodcock@harrisirwin.com>
Subject: FW: Planning consultation - DM/26/0003 3-25 Bolnore Road, Haywards Heath, RH16 4AB

Dear Mr Woodcock

Please see WSFRS comments. I would be grateful for your response in due course.

Many thanks

Andy Watt, BSc (Hons), MTPL, MRTPI
Senior Planning Officer
Development Management
01444 477517
andy.watt@midsussex.gov.uk
www.midsussex.gov.uk

Working together for a Better Mid Sussex

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 09 January 2026 10:55
To: planninginfo <planninginfo@midsussex.gov.uk>
Subject: Planning consultation - DM/26/0003 3-25 Bolnore Road, Haywards Heath, RH16 4AB

FAO: Andrew Watt

Dear Andrew,

Having viewed the details provided for Planning Application No. DM/26/0003 for the discharge of condition 15 fire hydrant provision details, the fire hydrant (FH) indicated on the plan is not considered suitable by West Sussex Fire & Rescue Service (WSFRS) as the FH is supplied by and fitted to a 3" – 75mm main, this not considered suitable for a commercial property. With the drop in mains water pressures across the Country, these smaller water mains sizes will not provide a sufficient flow rate to keep a fire appliance supplied with water whilst attending a fire,

which then puts residents and property at greater risk, for this reason the proposed FH is not suitable for WSFRS to adopt, and does not comply with the FH condition raised.

From the plan submitted, there is a 6" - 150mm main near the new build care home, with 90m of the entrance to the care home and would be considered suitable if the FH was supplied by and fitted to this main, I have attached a marked up plan to show the FH could be installed on a 6" main.

Regards
Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051


Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his 

[Click here to find out why we use pronouns in our signatures](#)



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software

viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.