

Delegated Decision

Sign off Sheet

Ref. No:	DM/24/2899	Case Officer:	Peter Davies
Application Type:	Lawful Development Certificate -Proposed		
Proposal:	Proposed loft conversion with hip to gable and rear dormer		
Site:	4 King George Avenue, East Grinstead, West Sussex, RH19 2AS, , , ,		
Validation Date	27 Nov 2024	Overall Expiry Date:	23 Dec 2024
Pre-Commencement Conditions Required:		Pre-Com Conditions Date Agreed:	
Recommendation:	Permission	Recommendation Date:	13 Jan 2025
Target Date:	22 Jan 2025	Recommending Officer Signature:	Peter Davies

Date Legal Agreement Completed: (if applicable)		No of Representations:	0
---	--	------------------------	---

Signed and Agreed By:	Steven King	Date:	13 Jan 2025
Comments:			

MID SUSSEX DISTRICT COUNCIL

DM/24/2899

**4 King George Avenue, East Grinstead, West Sussex, RH19 2AS, , ,
Proposed loft conversion with hip to gable and rear dormer
Mr Jamie Rivers**

REPRESENTATIONS

None received.

TOWN COUNCIL OBSERVATIONS

None received.

INTRODUCTION

This application seeks a Lawful Development Certificate for a proposed loft conversion with hip to gable extension and rear dormer.

RELEVANT PLANNING HISTORY

None relevant.

SITE AND SURROUNDINGS

The application property is a semi detached two storey dwelling located on the north side of King George Avenue, within the built-up area boundary of East Grinstead.

The application property has a hipped roof and is constructed from grey render with anthracite fenestration faux slate roof. The dwelling is set back from the highway with off street parking. The locality is characterised by brick semi-detached two storey dwellings of a similar scale and design.

APPLICATION DETAILS

The proposed hip to gable extension will be located on the southeast side of the dwelling with a dormer on the northeast. The dormer will have a width and depth of 6.257 metres and 3.577 metres. The dormer will have a flat roof with a height of 3.0 metres.

Two no. rooflights are to be installed on the front elevation roof slope which will not protrude more than 0.15 metres. One no. side window is to be installed on the gable end elevation which will be obscure glazed and non-opening.

All external materials will be similar in appearance to the existing dwelling.

LEGAL FRAMEWORK

This application is to establish whether the proposed development would benefit from permitted development rights and will be a legal decision; planning merits cannot be taken into account when considering this application.

The proposal will be tested against the relevant criteria of Part 1 Classes B and C Schedule 2 of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended), as detailed below:

Permitted Development

Class B - The enlargement of a dwellinghouse consisting of an addition or alteration to its roof.

Development Not Permitted

B.1 Development is not permitted by Class B if—

- (a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P or Q of Part 3 of this Schedule;
- (b) any part of the dwellinghouse would, as a result of the works, exceed the height of the highest part of the existing roof;
- (c) any part of the dwellinghouse would, as a result of the works, extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway;
- (d) the cubic content of the resulting roof space would exceed the cubic content of the original roof space by more than—
 - (i) 40 cubic metres in the case of a terrace house, or
 - (ii) 50 cubic metres in any other case;
- (e) it would consist of or include—
 - (i) the construction or provision of a veranda, balcony or raised platform, or
 - (ii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe; or
- (f) the dwellinghouse is on article 2(3) land.

Conditions

B.2 Development is permitted by Class B subject to the following conditions—

- (a) the materials used in any exterior work shall be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;
- (b) the enlargement must be constructed so that -
 - (i) other than in the case of a hip-to-gable enlargement or an enlargement which joins the original roof to the roof of a rear or side extension -
 - (aa) the eaves of the original roof are maintained or reinstated; and
 - (bb) the edge of the enlargement closest to the eaves of the original roof is, so far as practicable, not less than 0.2 metres from the eaves, measured along the roof slope from the outside edge of the eaves; and
 - (ii) other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension, no part of the enlargement extends beyond the outside face of any external wall of the original dwellinghouse; and
- (c) any window inserted on a wall or roof slope forming a side elevation of the dwellinghouse shall be—
 - (i) obscure-glazed, and
 - (ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed.

Interpretation of Class B

B.3 For the purposes of Class B "resulting roof space" means the roof space as enlarged, taking into account any enlargement to the original roof space, whether permitted by this Class or not.

B.4 For the purposes of paragraph B.2(b)(ii), roof tiles, guttering, fascias, barge boards and other minor roof details overhanging the external wall of the original dwellinghouse are not to be considered part of the enlargement.

Class C - Any other alteration to the roof of a dwellinghouse.

Development Not Permitted

C.1 Development is not permitted by Class C if—

- (a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P or Q of Part 3 of this Schedule (changes of use);
- (b) the alteration would protrude more than 0.15 metres beyond the plane of the slope of the original roof when measured from the perpendicular with the external surface of the original roof;
- (c) it would result in the highest part of the alteration being higher than the highest part of the original roof; or
- (d) it would consist of or include—
 - (i) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or
 - (ii) the installation, alteration or replacement of solar photovoltaics or solar thermal equipment.

Conditions

C.2 Development is permitted by Class C subject to the condition that any window located on a roof slope forming a side elevation of the dwellinghouse must be—

- (a) obscure-glazed; and
- (b) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed.

ASSESSMENT

The property's planning history has been checked and household permitted development rights are understood to be intact for the element proposed. The property is not located on Article 2(3) land or subject to an Article 4 Direction.

The proposed enlargement would be situated within the curtilage of the dwellinghouse and the location, dimensions, and volume (48.2 cubic metres) of the proposal complies with applicable criteria of Classes B and C. The exterior materials of the proposed works would be similar in appearance to the materials of the exterior of the existing dwellinghouse.

CONCLUSION

In conclusion, the proposed development is deemed to comply with the applicable permitted development criteria as set out within Classes B and C of Part 1 Schedule 2 of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended) and therefore a certificate can be issued.

Decision: Permission

Case Officer: Peter Davies