

Joanne Fisher

From: [REDACTED]
Sent: 24 February 2025 15:24
To: John Bullivant
Subject: Moody Sewage - Existing pumping station


Hi John

Further to your email I confirm that the existing piping station should be acceptable for up to 12 people in full time residency:-

1. Using standard models 12 people generate 2,160 litres of sewage per day.
2. The pump is running at the required 2 litres per second discharge rate into the public sewer.
3. Therefore total daily pump operational time for the calculated flow is 1,080 seconds, which is the equivalent of 18 minutes per day.

I trust that this clarifies this element of the system for you.

Kind Regards



Moody Sewage Ltd. We are registered in England and Wales: 6767655. Registered Office: 254 Upper Shoreham Road Shoreham By Sea BN43 6BF