

From: Oliver Benson <Oliver.Benson@midsussex.gov.uk>
Sent: 09 May 2025 16:32:11 UTC+01:00
To: "Joanne Fisher" <Joanne.Fisher@midsussex.gov.uk>
Subject: DM/25/0898 - SHELL BURGESS HILL, SERVICE STATION, 173 LONDON ROAD,
BURGESS HILL

Hi Jo,

I have reviewed the information submitted from purified air, which has risk rated the potential impact from odour from the Prett kitchen as low to medium.

On this basis, it appears they recommend that there are several possible systems they could install, most likely as an ESP particulate control unit followed by ON 100 Odour Control Unit.


It would be good to clarify exactly what odour control will be put in place, before we discharge the odour condition.

Also, the applicant should ensure the ventilation system does not cause a noise issue.

Many thanks,

Ollie

Oliver Benson
Senior Environmental Health Officer
Environmental Protection Team
Tel: 01444 477 059
Email: oliver.benson@midsussex.gov.uk
Website: www.midsussex.gov.uk



“Working together for a better Mid Sussex”