

From: drainage <drainage@midsussex.gov.uk>
Sent: 20 March 2026 15:14:07 UTC+00:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2026.03.20 Re: DM/26/0663 - 1a Lodgelands, Ardingly, Haywards Heath
Attachments: MSDC002 - Detailed Drainage Design Checklist - v2.0 issued 071125.pdf,
MSDC002 - Detailed Drainage Design Technical Summary - v2.0 issued 071125.pdf, FW: Discharge of
conditions application DM/26/0663 - 1A Lodgelands, Ardingly, Haywards Heath

Dear Anna,

Following your recent email as attached of which I responded directly to, I also requested the Engineers comments. They note that from the recent submission, only a simple layout was included, and no calculations have been provided.

Our Detailed Drainage Design checklist for the Discharge of Condition Stage design was updated in November 2025. This level of information is required at the discharge condition stage.

We would recommend the applicant reviews the checklist which includes all our requirements. Please see attached documents for guidance.

Best Wishes
Emma

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk