

From: Emma Rivett <Emma.Rivett@midsussex.gov.uk>
Sent: 03 July 2026 11:43:05 UTC+01:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Subject: DM/26/1132 - Land North of Nos. 42-54 Hurst Road, Hurstpierpoint

Dear Anna,

I have looked at the information provided with this application and noticed that there is no tree information.

I note from the photographs and what you described when we talked about the proposal, that there will be some surfacing within the root protection areas of some of the tree and that there will be some excavation works in proximity to trees. I would need an Arboricultural Impact Assessment, including a Tree Constraints Plan and Tree Survey, and where root protection areas are affected or likely impacted by the development, an Arboricultural Method Statement and Tree Protection Plan would be required. Please could you request these?

Please reconsult me once these have been provided and I can then make more fully informed comments.

Kind regards

Emma

Emma Rivett
Assistant Tree Officer-Development Management
www.midsussex.gov.uk

Working together for a better Mid Sussex