

**From:** Adam Humphrey <adam@mjhumphrey.co.uk>  
**Sent:** 06 February 2026 07:19:50 UTC+00:00  
**To:** "Anna Tidey" <anna.tidey@midsussex.gov.uk>  
**Cc:** "Emma Poland" <emmapoland@aol.com>; "Rainier, Peter" <peter.rainier@dmhstallard.com>  
**Subject:** Re: DM/25/3176 - Land Adj To The Meadows Little Park Farm Marchants Close Hurstpierpoint Hassocks West Sussex BN6 9UZ  
**Attachments:** C3917\_LLFA Response.pdf, C3917\_P2\_SW & FW Drainage Report.pdf, SW Calculations\_02.02.2026.pdf, Unknown.pdf

Hi Anna,

Please find attached additional supporting information to satisfy the FR and D team queries.

Kind Regards

Adam Humphrey, MCIQB BSc (Hons)

07812419142

[adam@mjhumphrey.co.uk](mailto:adam@mjhumphrey.co.uk)

21 Pendine Avenue  
Worthing  
West Sussex  
BN11 2NA

**M.J.Humphrey Ltd**

On 23 Jan 2026, at 08:53, Anna Tidey <anna.tidey@midsussex.gov.uk> wrote:

Dear Adam and Mel

I have received the attached comments from the Flood Risk and Drainage (FR&D) Team regarding this application this morning.

As you will see additional supporting information has been requested. Upon receipt of this further information I will reconsult the FR&D Team. This may delay the determination of the application.

I look forward to receiving the requested information.

Regards


Anna

-----  
Submit your planning application online.  
<http://www.planningportal.gov.uk>  
-----

Anna Tidey BA(Hons) MPhil MRTPI  
Planning Officer  
Development Management

Tel: +44 (0)1444 477342

[anna.tidey@midsussex.gov.uk](mailto:anna.tidey@midsussex.gov.uk) <http://www.midsussex.gov.uk>



Working together for a Better Mid Sussex.



**- SAVE A TREE** Only print this email if absolutely necessary.

---

**From:** drainage <[drainage@midsussex.gov.uk](mailto:drainage@midsussex.gov.uk)>

**Sent:** 22 January 2026 19:43

**To:** Anna Tidey <[anna.tidey@midsussex.gov.uk](mailto:anna.tidey@midsussex.gov.uk)>

**Cc:** drainage <[drainage@midsussex.gov.uk](mailto:drainage@midsussex.gov.uk)>

**Subject:** 2026.01.22 Re: DM/25/3176 - Land Adj To The Meadows Little Park Farm  
Marchants Close Hurstpierpoint Hassocks West Sussex BN6 9UZ

Dear Anna,

Thank you for consulting the Flood Risk and Drainage Team on the above application.

We understand the proposed application is for a dwelling, detached three-bedroom chalet bungalow.

We have reviewed the Foul and Surface Water Drainage Report (Date; 10/12/2025 prepared by CGS Civils) and have the following comments.

At this stage of planning, additional information is required to demonstrate that the proposed drainage strategy is acceptable in principle.

At this time, we will require the following further information:

**Surface Water Drainage**

- Ownership of the ditch.
- Evidence of the ditch described within the drainage strategy exists.
- Evidence that the invert levels of the ditch are sufficient to accommodate the proposed drainage outfall.
- Evidence that the receiving ditch has capacity.
- Evidence that the ditch has a wider connection to the drainage / watercourse network in the area.

**Foul Water Drainage**

- A measured drainage layout plan demonstrating that the proposed package treatment plant achieves the minimum offset distances from buildings, boundaries, and water features.
- We would advise the applicant that the system will need to either meet with the Environment Agency's General Binding Rules for package treatment plants, or an Environmental Permit will be required from the Environment Agency.

The applicant should refer to the MSDC Flood Risk and Drainage Information Check List (Application Stage) and the Strategic Flood Risk Assessment Map available at: <https://www.midsussex.gov.uk/planning-building/flood-risk-and-drainage-for-planning/>

Upon receipt of the additional information requested above, the Flood Risk and Drainage Team will review the submission and provide further comment.

Receipt of the requested additional information does not mean further information will not be requested, nor does it guarantee that the Flood Risk and Drainage Team will not object to the development. Neither does it prevent the team from recommending a flood risk or drainage condition.

Best Wishes

**Flood Risk and Drainage Team**  
**Estate Services and Building Control**  
**Mid Sussex District Council**  
[drainage@midsussex.gov.uk](mailto:drainage@midsussex.gov.uk)

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.