

From: drainage <drainage@midsussex.gov.uk>
Sent: 02 October 2025 17:48:01 UTC+01:00
To: "Susan Dubberley" <Susan.Dubberley@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2025.10.02 Re: DM/25/1980 - Sackville School, Lewes Road, East Grinstead, West Sussex

Dear Susan,

The flood risk and drainage team have begun reviewing the information submitted in support of this application and can provide the following initial comments.

It is proposed for each artificial pitch to discharge at 4.5 l/s into a watercourse with attenuation provided within the sub-grade materials of the pitches.

Following an initial review of the application it appears that no calculations have been provided as part of the condition discharge submission. Invert and cover levels should also be provided for all proposed discharge pipework.

No consideration has been provided regarding the impact of a flooded outfall.

Upon receipt of this additional information, we will be able to comment further. Receipt of the requested additional information does not mean further information will not be requested.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk