



Mid Sussex District Council
Oaklands
Oaklands Road
Haywards Heath
West Sussex
RH16 1SS

Your ref
DM/26/1735

Our ref
DSA000056501

Date
10th August 2026

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Single storey side extension with low profile roof lights, removal of existing conservatory
Site: More House, Copyhold Lane, Cuckfield, Haywards Heath, RH17 5EB.

Thank you for your **correspondence**, please see our comments below regarding the above application.

Development Site is not within Southern Water's Water Supply Area

The development site is not located within Southern Water's statutory area for water supply services. Please contact South East Water, who are the relevant statutory undertaker.

Proposed works involve demolition.

In order to protect and safeguard the existing water supply apparatus, Southern Water requests formal notification of any proposed demolition works prior to such works being undertaken.

Rear/side extension, No Sewer mapped

Due to legislative changes, certain Southern Water sewers are not comprehensively mapped. There are no public sewers recorded within the site boundary. However, the relevant requirements, conditions and application associated with the build-over/close-to a public sewer are available at Southern Water's Get Connected service: <https://developerservices.southernwater.co.uk>.

Please note, surface water should not be disposed of into a public foul sewer and must comply with the Hierarchy of H3 of the Building Regulations. For more details, refer to the Drainage and Waste Disposal: Approved Document H on the GOV.UK website.

Any new connections to the public sewerage system will require a New Sewer Connection application (also known as a Section 106) to be submitted and approved by Southern Water.

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670



Due to legislative changes effective from 1st October 2011 regarding the ownership of sewers, it is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction work, an investigation of the sewer will be required to ascertain its ownership before any work commences on site. If this happens, please call our Customer Service Desk on 0330 303 0119.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team

southernwater.co.uk/developing-building/planning-your-development