

From: Nicholas Bennett <Nicholas.Bennett@midsussex.gov.uk>
Sent: 21 September 2026 13:48:01 UTC+01:00
To: "Steven King" <Steven.King@midsussex.gov.uk>
Subject: RE: DM/26/1898 - Discharge of planning conditions 8, 10, 12, 13 and 14 relating to planning application DM/23/2699.

Hi Steve

I am not sure if someone responded on my behalf or not, but yes, I agree that this is sufficient to allow discharge.

Regards

Nick Bennett – S.E.H.O. | [Environmental Protection](#) | [Mid Sussex District Council](#) | 01444 477292

From: Steven King <Steven.King@midsussex.gov.uk>
Sent: 10 September 2026 13:19
To: Nicholas Bennett <Nicholas.Bennett@midsussex.gov.uk>; pollution <pollution@midsussex.gov.uk>
Subject: RE: DM/26/1898 - Discharge of planning conditions 8, 10, 12, 13 and 14 relating to planning application DM/23/2699.

Hi Nick

I've received confirmation from the applicant re the times for the lighting as follows:

'To reclarify, the programmable time clock will be time restricted to the hours of operation of the sports pitches and athletics track as per condition 15, that is to say only 08:00 to 22:00 Monday to Saturday and 08:00 to 20:00 on Sundays and bank holidays. The attached manual for the proposed timer clock controller confirms this functionality.'

This seems fine to me. I've copied in the generic e mail as I see you're on leave until 21st September and I'd like to get this condition discharged as soon as possible.

Regards

Steven King, BSc (Hons) Dip TP, MRTPI
Team Leader, Major Development
Mid Sussex District Council
01444 477556

Steven.King@midsussex.gov.uk
www.midsussex.gov.uk



Working together for a better Mid Sussex

From: Nicholas Bennett <Nicholas.Bennett@midsussex.gov.uk>

Sent: 25 August 2026 16:46

To: Steven King <Steven.King@midsussex.gov.uk>

Subject: DM/26/1898 - Discharge of planning conditions 8, 10, 12, 13 and 14 relating to planning application DM/23/2699.

Hi Steve

Am sending responses by email currently due to the technical issues with the portal.
Here is my response for Cond 14 only:

Environmental Protection has no objection to the submitted lighting design, illuminance levels or light spill assessment. However, the submission does not appear to provide details of the measures to ensure the lighting is switched off when not in use, as required by Condition 14. Further details are requested before the condition is discharged.

Thanks

Nick Bennett – S.E.H.O. | [Environmental Protection](#) | [Mid Sussex District Council](#) | 01444 477292