

Our Ref: 8500277527

Planning Office
Mid Sussex District Council
Oaklands Road
Haywards Heath
West Sussex
RH16 1SS

31st January 2024

Dear Sir/Madam

Electricity Act 1989
Overhead Line (Exemption) (England & Wales) Regulations 2009
Statutory Instrument 2009 No. 640 Electricity, Paragraph 3 (1)

This notice is being given to your Council under The Overhead Lines (Exemption) (England & Wales) Regulation 2009.

Under this exemption, your Authority is required to determine, within 6 weeks of receipt of this notice, whether it is considered that the proposal is likely to have a significant adverse effect on the environment.

The works associated with this proposal will commence on site on or after the expiry of the required six weeks notice, unless it becomes necessary to apply to the Secretary of State for Trade and Industry for his consent.

Particulars of proposal:

Location: West Up Farm Deaks Lane RH17 5JB

Plan No: UKPN8500277527 1-500

Details of proposal:

- To replace the existing 50kVA pole mounted transformer (PMT) attached to pole 616344 with a 100kVA PMT
- To upgrade the overhead lines between poles 616344 and 632970 to 95ABC

Yours faithfully

Stessie Aristide
Connections Surveyor
South Eastern Power Networks plc
07935 085579
stessie.aristide@ukpowernetworks.co.uk