

From: Sussex Architectural Services <john.sergi@sussexarchitecturalservices.co.uk>
Sent: 13 May 2025 15:25:57 UTC+01:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Cc: "Rachelle Driscoll" <rachelle.driscoll@hotmail.com>
Subject: DM/25/0723 - 35 Beckworth Lane, Lindfield 'Overhead power line query'

Dear Anna

Thank you for your email and time today on the phone.

With regards to the overhead power line serving no's 35 and 34.

At Building Control stage we will propose to remove and refit the bracket currently affixed to the front facing 1st floor tile hanging of no 35 approximately 225mm lower than its current position, in order to avoid the new eaves to the proposed 'crown top' roof arrangement in this location. Alternatively if UK Power Networks require the bracket to be maintained at the current height it would be relocated on the side (flank) wall which will be unaffected by the proposals.

My client will obtain the necessary consent/s where required to do so from the statutory provider, in this instance UK power networks (SEPN).

Kind regards

John

CC: Client

John Sergi *BA hons (Arch), Dip Arch*
for Sussex Architectural Services
john.sergi@sussexarchitecturalservices.co.uk
www.sussexarchitecturalservices.co.uk
[tel: 01444 461720](tel:01444461720)



Sussex Architectural Services

Forthcoming office closures: 16-27 June inclusive