


From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 11 March 2026 08:03:31 UTC+00:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: Discharge Condition 15 Fire Hydrant requirement DM/26/0584 Burgess Hill Northern Arc, Land North And North West Of Burgess Hill, Between Bedelands Nature Reserve In The East And, Goddard's Green Waste Water Treatment Works In The West

FAO: Joseph Swift

Dear Joseph,

Having viewed the details submitted for the discharge of condition 15 – Fire Hydrants West Sussex Fire & Rescue Service have not received any confirmation that the fire hydrants identified have been or will be installed when the water main is laid, therefore the condition raised cannot be discharged until further information and confirmation is received.

Regards
Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frswaterandaccess@westsussex.gov.uk

Bognor Regis Fire Station, West Meads Drive, West Sussex, PO21 5TB



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
