

From: drainage <drainage@midsussex.gov.uk>
Sent: 11 March 2026 16:37:54 UTC+00:00
To: "Stefan Galyas" <Stefan.Galyas@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2026.03.11 Re: DM/26/0387 - 1 Withy Bush Burgess Hill West Sussex RH15 8TT

Dear Stefan,

Thank you for consulting the Flood Risk and Drainage Team on the above application.

We understand the proposed application is to remove existing conservatory and erect a two storey extension with alterations to main staircase to access extension.

The Flood Risk Assessment provided by FloodPlan Limited dated 26 February 2026 has been reviewed and we would comment as follows:

Flood Risk

[National Planning Policy Framework](#). This means that surface water flood risk extents should be considered comparable to flood zones when assessing a development's vulnerability to flooding and the need for a site-specific flood risk assessment.


For clarity Mid Sussex District Council's Flood Risk and Drainage Team (in line with advice from West Sussex Lead Local Flood Authority) utilise the below table when considering flood risk.

Annual exceedance	Flood Zone	Surface Water Flood Risk
Greater than 3.3% (>1:30-year)	3b	High
Between 1% and 3.3% (1:100-year and 1:30-year)	3a	Medium
Between 0.1% and 1% (1:1,000-year and 1:100-year)	2	Low
Less than 0.1% (<1:1,000-year)	1	Very Low

We acknowledge that some of this guidance still refers to flood zones, however it should be read as 'flood zone or equivalent'.

The submitted Flood Risk Assessment (FRA) confirms that the site lies within Flood Zone 1 and is therefore at very low risk of fluvial flooding.

However, the Environment Agency's Risk of Flooding from Surface Water (RoFSW) mapping indicates that the site is shown to be at very low to high surface water flood risk (comparable to Flood Zones 1 to 3b). The area of high surface water flood risk is associated with a flow path running from the rear to the front of the property.



In line with Planning Practice Guidance, surface water flood risk extents should be considered comparable to fluvial flood zones when assessing a development's vulnerability and the need for a site-specific Flood Risk Assessment. Based on the Council's adopted approach (aligned with West Sussex LLFA guidance), areas at greater than 3.3% Annual Exceedance Probability (AEP) (1 in 30-year event) are considered comparable to Flood Zone 3b (functional floodplain).

The proposal relates to a residential property, which is classified as 'more vulnerable' development (NPPF Annex 3).

The applicant has failed to demonstrate that the increase in built footprint is located outside of the 1 in 30-year surface water flood extent. In the absence of such evidence, and based on the latest flood risk mapping, part of the extension is considered to fall within the equivalent of Flood Zone 3b (functional floodplain).

Utilising the Flood Risk Vulnerability and Flood Zone Compatibility Table (PPG Paragraph 079), 'more vulnerable' development is not permitted within Flood Zone 3b.

Furthermore, the Environment Agency's standing advice for minor development confirms that development within the 1 in 30-year flood extent is not permissible.

The Flood Risk and Drainage Team, therefore, **Objects** to the proposed development as per the Environment Agency's standing advice for minor extensions; development within the 1:30 flood extent is not permissible.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk