

Florence,

I have found evidence that the recent development to the south of Barn Cottage discharges into the existing highway drain via a historic ditch around the site. Therefore, I'm happy for you to have a limited discharge from your site.

Your recent CCTV highlighted an issue at CP1, which appear to be a buried chamber. As part of your work can you please investigate this location further and uncover / raise CP1, for ease of future maintenance.

Regards,

Kevin

Kevin Macknay
Drainage and Flooding Lead Professional
Highways, Transport and Planning
Place Services
West Sussex County Council