

From: drainage <drainage@midsussex.gov.uk>
Sent: 23 October 2025 14:42:56 UTC+01:00
To: "Katherine Williams" <Katherine.Williams@midsussex.gov.uk>
Cc: "Steve Ashdown" <Steve.Ashdown@midsussex.gov.uk>; "drainage" <drainage@midsussex.gov.uk>
Subject: 2025.10.23 Re: DM/25/2472 - Queen Victoria Hospital, Holtye Road, East Grinstead, West Sussex

Dear Katherine,

The Flood Risk and Drainage Team have reviewed the submitted drainage statement (V3178-HUN-00-T-C-00-0001) and have the following comments:

The applicant should provide clear evidence demonstrating that infiltration SuDS are not viable at the site; otherwise, the drainage strategy should be revised to incorporate the results of BRE365 infiltration testing.

A CV value of 1 should be utilised within all calculations.

Upon receipt of this additional information, we will be able to comment further. Receipt of the requested additional information does not mean further information will not be requested.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk