

Project 5289 – Signage Lighting Assessment

Lighting Assessment

The site will have 2No entrance sign that will have overhead trough light.

The lights will be on timers linked to the overall site's external lighting and controlled by a timer.

- Winter Times – Morning 6am-9am, Afternoon 4pm – 11pm
- Summer Times - Afternoon 7pm - 11pm.

These times would be subject to change under the home management scheme.

The lights will be 1650 lumen 14.4W per metre 50,000 hour IP65 LED tape

6000k cool white or 3000k warm light