

From: Jess Sparkes <JSparkes@cala.co.uk>
Sent: 19 January 2026 16:19:45 UTC+00:00
To: "Stuart Malcolm" <stuart.malcolm@midsussex.gov.uk>
Cc: "Tracy Puttock" <tracy@ashill.co.uk>
Subject: RE: Brickworks - Response to application DM/25/1853 - outstanding conditions
Attachments: 0763-25-B-32 SANG Tree and Hedge Planting Plan 2 of 2 REV4.pdf, 0763-25-B-31 SANG Tree and Hedge Planting Plan 1 of 2 REV4.pdf

Good afternoon Stuart

Please find attached the updated SANG landscape plans.

- SANG Planting Plans 1 and 2 Rev 4 to replace Rev 3 submitted in October 2025.

These remove the Frangula alnus as requested by your Landscape Officer and replace it with Hazel as requested.

This only leaves canopy details to be submitted (Condition 3). Those are proving a little harder to source because they are not being procured yet but I am hoping for further detail soon.

On other matters, are there any comments from Housing on the M4(3) dwellings (Condition 19)?

Kind regards

Jess

Jessica Sparkes MRTPI | Head of Planning

E: jsparkes@cala.co.uk | M: 07792302696

Cala Homes South Home Counties, The Dorking Business Park, Station Road, Dorking, RH4 1HJ



Proud to support



CALA Homes (South Home Counties) Limited. Registered in England & Wales: 08800163. Registered office at: CALA House, 54 The Causeway, Staines-Upon-Thames, Surrey, TW18 3AX and acting for and on behalf of **CALA Management Limited** (SC013655) with its registered office at 5 Mid New Cultins, Edinburgh, EH11 4DU, Scotland.

Please consider the environment before printing this email.

From: Jess Sparkes

Sent: 12 January 2026 15:22

To: 'Stuart Malcolm' <stuart.malcolm@midsussex.gov.uk>

Cc: Tracy Puttock <tracy@ashill.co.uk>

Subject: RE: Brickworks - Response to application DM/25/1853 - outstanding conditions

Hi Stuart,

In terms of the detail I am pulling together to resubmit -

- **Soft landscape plans** – being updated and should be ready for resubmission by the end of this week.
- **Hard landscape detail/paving** etc – we will be using the 80mm Marshalls Key Block in Brindle to Private Driveways (see attached).
- **Canopies/railings** – with this I am struggling because we don't procure the detail yet. I should have a timeframe by the time I submit the soft landscape plans at the end of this week.

Kind regards,

Jess

Jessica Sparkes MRTPI | Head of Planning

E: jsparkes@cala.co.uk | M: 07792302696

Cala Homes South Home Counties, The Dorking Business Park, Station Road, Dorking, RH4 1HJ



Proud to support



CALA Homes (South Home Counties) Limited. Registered in England & Wales: 08800163. Registered office at: CALA House, 54 The Causeway, Staines-Upon-Thames, Surrey, TW18 3AX and acting for and on behalf of **CALA Management Limited** (SC013655) with its registered office at 5 Mid New Cultins, Edinburgh, EH11 4DU, Scotland.

Please consider the environment before printing this email.

From: Stuart Malcolm <stuart.malcolm@midsussex.gov.uk>

Sent: 08 January 2026 14:42

To: Jess Sparkes <JSparkes@cala.co.uk>

Cc: Tracy Puttock <tracy@ashill.co.uk>

Subject: RE: Brickworks - Response to application DM/25/1853 - outstanding conditions

Hi Jess thanks for the email. Do you know how long it will be until the remaining items are ready to submit? So as to ensure everything gets looked at in one go.

Regarding the hard landscaping, thanks for confirming the boundary treatment heights. In addition to this however I would like to see confirmation on the hard surface materials. For example, please be more specific than 'block paving' and include reference to colours, products etc.

Regarding soft landscaping, the landscape consultant has not made any further requests (22/12).

Many thanks

Stuart

From: Jess Sparkes <JSparkes@cala.co.uk>

Sent: 07 January 2026 11:24

To: Stuart Malcolm <stuart.malcolm@midsussex.gov.uk>

Cc: Tracy Puttock <tracy@ashill.co.uk>

Subject: Brickworks - Response to application DM/25/1853 - outstanding conditions

You don't often get email from jsparkes@cala.co.uk. [Learn why this is important](#)

Hi Stuart,

A very Happy New Year to you.

I have tidied up the original email exchange and removed conditions that have been discharged. Updated comments in red as follows:

Planning Conditions

- **DM/25/2498 – Condition 3 (1 in 20 drawings), and 19 (M4(3) properties)**

The EHO consultation response requests a copy of the Air Quality Statement – attached for ease. Can you please send this to Nick Bennett if he doesn't have a copy yet?

3 – Anna has commented as follows:

- *Window recess depths appear insufficient, with only half-brick depth, which may result in flat-looking elevations. Please revise. I have put this to my colleagues and await their response.*

- Please provide 1:20 sections and front elevations of typical entrance canopies/doors (shown in context). Please include confirmation on the front door colours. I believe this was not delivered yet. RAL Colour is 7016 for both front entrance and garage doors. Canopy detail to follow.
- Please provide External Material Schedule. See attached EMS submitted pursuant to Condition 2.
- Obscured windows on the ground floor level are not acceptable. This particularly applies to the Plot 86 which is a corner plot. Furthermore, I would suggest only the bottom half of the full-size bathroom windows to be obscured (e.g. Plot 72-73, 80 etc first floor). We will remove obscure glazing.
- Provide more information on the railing. To follow.
- Provide chimney detail. To follow
- I understand Vertically hang plain tiles is to replace some of the approved Weatherboarding in some places? If so, please update the Material Plan. We don't have any tile hanging so not sure where this has come from.
- At the moment dwg. No: SD/3003 dated Oct 2014 is not acceptable as it shows elevations which do not correspond with any of the approved elevations. Drawing submitted in error, no hanging tile.

19 – chased up housing and their comments are to come today or at start of next week. Are these available yet?

- **DM/25/1658 – Condition 4 (soft landscaping), 20 (play area), 27 (landscape management)**

Updated soft landscape information submitted 31 October – no further comments

4, 20 and 27 – awaiting further landscape comments. But tree officer has confirmed that she is broadly happy with changes although has questioned the replacement of Sambucus in the SANG with Frangula alnus. Whilst it is native to specific parts of the UK, it is not endemic to this area at all, and, therefore, not really appropriate. It is suggested to replace it with holly or hazel. Please confirm.

Are there any further landscape comments before we amend the holly/hawthorn as requested?

- **DM/25/1929 – Condition 5 (hard landscape)**

Consultees raise no objection

5 – awaiting further information on specific materials/products for hard landscaping scheme. Submitted information refers to 6 External Works Sheets but these do not include this specific info. Need all boundary treatment heights shown too

We have added boundary treatment heights to the External Works Plans – see attached.

S106 Obligations

- DM/25/1765 – SANG Spec (Clause 7, Schedule 1)
- DM/25/1766 – Management Spec (Clause 8, Schedule 1)

◦ Further comments to come from officers

The Travel Plan (Clause 4, Schedule 1) was approved on 19.5.25 as per the attached email from Ian Gledhill. Nothing has been received concerning the Public Right of Way detail submitted at the same time. Clause 1.1 in Schedule 3 is vague, can we presume the submitted PRow details are acceptable?

I would not recommend assuming this, please contact the Public Rights of Way team at WSCC directly. WSCC PRow officer is happy with the submission – please see attached email dated 17 December FYI.

Kind regards,

Jess

Jessica Sparkes MRTPI | Head of Planning

E: jsparkes@cala.co.uk | M: 07792302696

Cala Homes South Home Counties, The Dorking Business Park, Station Road, Dorking, RH4 1HJ



Proud to support



CALA Homes (South Home Counties) Limited. Registered in England & Wales: 08800163. Registered office at: CALA House, 54 The Causeway, Staines-Upon-Thames, Surrey, TW18 3AX and acting for and on behalf of **CALA Management Limited** (SC013655) with its registered office at 5 Mid New Cultins, Edinburgh, EH11 4DU, Scotland.

Please consider the environment before printing this email.

From: Jess Sparkes
Sent: 12 December 2025 14:18
To: 'Stuart Malcolm' <stuart.malcolm@midsussex.gov.uk>
Subject: RE: Response to application DM/25/1853

Hi Stuart

Just a couple of queries in red below against condition 3 and 5. This will help me when I provide a proper response.

Kind regards,

Jess

Jessica Sparkes MRTPI | Head of Planning

E: jsparkes@cala.co.uk | M: 07792302696

Cala Homes South Home Counties, The Dorking Business Park, Station Road, Dorking, RH4 1HJ



Proud to support



CALA Homes (South Home Counties) Limited. Registered in England & Wales: 08800163. Registered office at: CALA House, 54 The Causeway, Staines-Upon-Thames, Surrey, TW18 3AX and acting for and on behalf of **CALA Management Limited** (SC013655) with its registered office at 5 Mid New Cultins, Edinburgh, EH11 4DU, Scotland.

Please consider the environment before printing this email.

From: Stuart Malcolm <stuart.malcolm@midsussex.gov.uk>

Sent: 12 December 2025 13:15

To: Ben Boyce <Ben@ashill.co.uk>

Cc: Jess Sparkes <jsparkes@cala.co.uk>; Tracy Puttock <tracy@ashill.co.uk>

Subject: RE: Response to application DM/25/1853

Hi all

Apologies for the delay, I am still awaiting some consultee comments but also wanted to give you an update on all the conditions where I can. So please see below my comments in blue.

Thanks

Stuart

From: Ben Boyce <Ben@ashill.co.uk>

Sent: 18 November 2025 15:29

To: Stuart Malcolm <stuart.malcolm@midsussex.gov.uk>

Cc: Jess Sparkes <jsparkes@cala.co.uk>; Tracy Puttock <tracy@ashill.co.uk>

Subject: RE: Response to application DM/25/1853

Good afternoon Stuart

I hope you are well.

We thought it would be helpful to review the various Brickworks submissions, re-submissions and comments from consultees. As a few are outstanding, we have listed out the submissions below, those highlighted orange are pending (following the submission of amended/updated info) but those highlighted green are acceptable as far as we know. It would be nice if a few could now be discharged.

Planning Conditions

- **DM/25/2498 – Condition 3 (1 in 20 drawings), 9 (air quality mitigation), 18 (fire hydrants) and 19 (M4(3) properties)**

The EHO consultation response requests a copy of the Air Quality Statement – attached for ease. Can you please send this to Nick Bennett if he doesn't have a copy yet?

3 – Anna has commented as follows:

- *Window recess depths appear insufficient, with only half-brick depth, which may result in flat-looking elevations. Please revise.*
- *Please provide 1:20 sections and front elevations of typical entrance canopies/doors (shown in context). Please include confirmation on the front door colours. I believe this was not delivered yet.*
- *Please provide External Material Schedule. I submitted the attached EMS for Condition 2. Would this do the trick for C.3 also? If so, when I respond properly I will attach that.*
- *Obscured windows on the ground floor level are not acceptable. This particularly applies to the Plot 86 which is a corner plot. Furthermore, I would suggest only the bottom half of the full-size bathroom windows to be obscured (e.g. Plot 72-73, 80 etc first floor).*
- *Provide more information on the railing.*
- *Provide chimney detail.*
- *I understand Vertically hang plain tiles is to replace some of the approved Weatherboarding in some places? If so, please update the Material Plan.*
- *At the moment dwg. No: SD/3003 dated Oct 2014 is not acceptable as it shows elevations which do not correspond with any of the approved elevations.*

9 – details acceptable, condition cleared.

18 – details acceptable, condition cleared.

19 – chased up housing and their comments are to come today or at start of next week.

- **DM/25/1853 – Condition 2 (materials), 6 (levels) and 7 (drainage)**

Additional drainage information submitted 6 November 2025 pursuant to condition 7

Window sample submitted mid-October pursuant to Condition 2.

All other materials details are acceptable we believe.

2 – details acceptable, new window sample ok, condition cleared

6 – details acceptable, condition cleared.

7 – awaiting further consultee comments

- **DM/25/1658 – Condition 4 (soft landscaping), 20 (play area), 27 (landscape management)**

Updated soft landscape information submitted 31 October – no further comments

4, 20 and 27 – awaiting further landscape comments. But tree officer has confirmed that she is broadly happy with changes although has questioned the replacement of Sambucus in the SANG with Frangula alnus. Whilst it is native to specific parts of the UK, it is not endemic to this area at all, and, therefore, not really appropriate. It is suggested to replace it with holly or hazel. Please confirm.

- **DM/25/1929 – Condition 5 (hard landscape), 26 (piling) and 28 (lighting)**

Consultees raise no objection

5 – awaiting further information on specific materials/products for hard landscaping scheme. Submitted information refers to 6 External Works Sheets but these do not include this specific info. Need all boundary treatment heights shown too I can add the heights easily but where is the info request for specific materials and products? I cant see that in a consultation response for this submission so am not 100% what to provide.

26 – details acceptable, condition cleared.

28 – details acceptable, condition cleared.

S106 Obligations

- DM/25/1765 – SANG Spec (Clause 7, Schedule 1)
- DM/25/1766 – Management Spec (Clause 8, Schedule 1)

o Further comments to come from officers

The Travel Plan (Clause 4, Schedule 1) was approved on 19.5.25 as per the attached email from Ian Gledhill. Nothing has been received concerning the Public Right of Way detail submitted at the same time. Clause 1.1 in Schedule 3 is vague, can we presume the submitted PRow details are acceptable?

I would not recommend assuming this, please contact the Public Rights of Way team at WSCC directly.

I trust the above summary is helpful but do let me or Tracy know if you have any queries.

Thanks

Ben

Ben Boyce | Director
ben@ashill.co.uk | 07899 890668

Ashill
Swan Court, 11 Worple Road,
Wimbledon, London, SW19 4JS
www.ashill.co.uk

From: Tracy Puttock <tracy@ashill.co.uk>
Sent: 06 November 2025 12:39
To: Stuart Malcolm <stuart.malcolm@midsussex.gov.uk>
Cc: Ben Boyce <Ben@ashill.co.uk>
Subject: RE: Response to application DM/25/1853

Dear Stuart,

Apologies for the delay but we now have a full updated drainage pack for resubmission to respond to the LLFA consultation (attached) and missing bit of text (e-mail below).

The updated information is available here:

<https://www.dropbox.com/scl/fo/4kzjjy4zj5pu12zj9b6rk/ANPZrqicPUi60A2rou7LCIA?rlkey=0ridrkcyj3bppu9s374ky6tf9h&dl=0>

Please let me know if you can open the RSK link in dropbox – If not I can send a link to our own files instead.

Thanks

Tracy

Tracy Puttock | Planning & Development Manager
tracy@ashill.co.uk | 07887 761878

Ashill
Swan Court, 11 Worple Road,
Wimbledon, London, SW19 4JS
www.ashill.co.uk

From: Stuart Malcolm <stuart.malcolm@midsussex.gov.uk>
Sent: 15 September 2025 15:55
To: Tracy Puttock <tracy@ashill.co.uk>
Subject: FW: Response to application DM/25/1853

Hi Tracy

Please see the below

Thanks

Stuart

From: Eleanor Read <Eleanor.Read@westsussex.gov.uk>
Sent: 15 September 2025 15:53
To: Stuart Malcolm <stuart.malcolm@midsussex.gov.uk>
Subject: RE: Response to application DM/25/1853

You don't often get email from eleanor.read@westsussex.gov.uk. [Learn why this is important](#)

Hi Stuart,

Apologies for delayed reply. Point 5 should have said:

In the FRA approved at full planning, we believe it says that additional survey work was needed in for the access road in the south of the site. In the DoC drawing, it still says additional survey work is needed. For a DoC application, the survey work should have been completed by now to inform the detailed drainage design work. Without knowing the invert levels for the outfall we are unable to check flood risk will not increase elsewhere.

Kind regards,

Ellie

Eleanor Read

Flood Risk Management Officer | Flood Risk Management Team
West Sussex County Council, Ground Floor, Northleigh, County Hall, Chichester PO19 1RH
Internal Phone: 227048 | External Phone: 03302 227048
Email: eleanor.read@westsussex.gov.uk | Web: www.westsussex.gov.uk

From: Natalie Biddulph <Natalie.Biddulph@westsussex.gov.uk> **On Behalf Of** Flood Risk Management
Sent: 14 August 2025 13:23
To: Stuart Malcolm <Stuart.Malcolm@midsussex.gov.uk>; Flood Risk Management
<floodriskmanagement@westsussex.gov.uk>
Subject: RE: Response to application DM/25/1853

Hi Stuart,

Unfortunately Eleanor is currently on leave, however I will flag with her upon her return at the end of next week,
Please do bear with us on the interim.

Kind Regards

Natalie Biddulph

Flood Risk Management Officer | Planning Services
West Sussex County Council, Ground Floor, Northleigh, County Hall, Chichester PO19 1RH
Email: FRM@westsussex.gov.uk | Web: www.westsussex.gov.uk

From: Stuart Malcolm <Stuart.Malcolm@midsussex.gov.uk>
Sent: 13 August 2025 16:42
To: Flood Risk Management <FRM@westsussex.gov.uk>
Subject: FW: Response to application DM/25/1853

****EXTERNAL****

Hi

Please see the below/attached and confirm what point 5 is meant to say in full.

Many thanks!

Stuart

From: Tracy Puttock <tracy@ashill.co.uk>
Sent: 12 August 2025 15:55
To: Stuart Malcolm <Stuart.Malcolm@midsussex.gov.uk>

Cc: Ben Boyce <Ben@ashill.co.uk>

Subject: RE: Response to application DM/25/1853

Hi Stuart

In the attached, point 5 is incomplete -

- In the FRA approved at full planning, we believe it says the.....

Would you mind asking Eleanor to resend with the full text please?

Thanks

Tracy

Tracy Puttock | Planning & Development Manager
tracy@ashill.co.uk | 07887 761878

Ashill

Swan Court, 11 Worple Road,
Wimbledon, London, SW19 4JS
www.ashill.co.uk

From: Stuart Malcolm <Stuart.Malcolm@midsussex.gov.uk>

Sent: 07 August 2025 15:02

To: Tracy Puttock <tracy@ashill.co.uk>

Subject: FW: Response to application DM/25/1853

Hi Tracy

Please see the attached which requires attention

Thanks

Stuart

From: planninghighways@westsussex.gov.uk <planninghighways@westsussex.gov.uk>

Sent: 07 August 2025 13:19

To: planninginfo <planninginfo@midsussex.gov.uk>

Subject: Response to application DM/25/1853

Please could the attached response be distributed to the relevant case officer.

Regards

Flood Risk Management

Please do not reply directly to this email.

Any formal reconsultation on the application should be directed to SULocalDevelopment@westsussex.gov.uk but the responding officer can be contacted directly via email if there are any questions relating to this response.

LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within

this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.

CAUTION: This email originated from outside of the organisation. Do not click links or open attachments unless you recognise the sender and know the content is safe.

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.

Please note and read these warnings and requirements:

This email and its contents are subject to contract and is not to be taken as indicating any intention whatsoever on the part of CALA Management Limited or any member of the CALA Group to form a legally binding agreement in relation to all or any of the matters referred to in it.

Confidentiality:- This email transmission is strictly confidential and intended solely for the addressee. It may contain privileged and confidential information and if you are not the intended recipient you must not copy or distribute it. If you have received this email in error, please notify the sender and delete the email transmission immediately.

Viruses:- Although we have taken steps to ensure that this email and attachments are free from any virus, we advise that in keeping with good computing practice the recipient should ensure they are actually virus free.

Security Warning:- Please note that this email has been created in the knowledge that internet email is not a 100% secure communications medium. We advise that you understand this lack of security and take any necessary measures when emailing us.

Privacy:- We reserve the right to read any email or attachment entering or leaving our systems from any source without prior notice.

CALA Group Limited, Registered in Scotland, Company Number SC326357; CALA 1999 Limited, Registered in Scotland, Company Number SC194813; CALA Management Limited, Registered in Scotland Company Number SC013655; all with Registered Office at Adam House, 5 Mid New Cultins, Edinburgh EH11 4DU

CALA Homes (East) Limited, Registered in Scotland, Company Number SC053746; CALA Homes (West) Limited, Registered in Scotland, Company Number SC222577;

CALA Homes (North) Limited, Registered in Scotland, Company Number SC465071; all with Registered Office at Johnstone House, 52-54 Rose Street, Aberdeen AB10 1HA; all Agents of CALA Management Limited

CALA Homes (Thames) Limited, Registered in England, Company Number 02522271; CALA Homes (Midlands) Limited, Registered in England, Company Number 00682410; CALA Homes (Chiltern) Limited, Registered in England, Company Number 09088106; CALA Homes (North Home Counties) Limited, Registered in England, Company Number 08800064, CALA Homes (South Home Counties) Limited, Registered in England, Company Number 08800163; all with Registered Office at CALA House, 54 The Causeway, Staines TW18 3AX; all Agents of CALA Management Limited

Banner Management Limited, Registered in England, Company Number 03351227; Banner Construction Limited, Registered in England, Company Number 01457331; Banner Homes Midlands Limited, Registered in England, Company Number 01091164; Banner Homes Southern Limited, Registered in England, Company Number 01453522; Banner Homes Ventures Limited, Registered in England, Company Number 08026864; Banner Homes Group Limited, Registered in England, Company Number 03647340; Banner Homes Bentley Priory Limited, Registered in England, Company Number 08082535; Banner Homes Central Limited, Registered in England, Company Number 01067052; Banner Developments Limited, Registered in England, Company Number 04046706; Banner Freehold Limited, Registered in England, Company Number 4824344; all with Registered Office at CALA House, 54 The Causeway, Staines TW18 3AX

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.

**

Please note and read these warnings and requirements:

This email and its contents are subject to contract and is not to be taken as indicating any intention whatsoever on the part of CALA Management Limited or any member of the CALA Group to form a legally binding agreement in relation to all or any of the matters referred to in it.

Confidentiality:- This email transmission is strictly confidential and intended solely for the addressee. It may contain privileged and confidential information and if you are not the intended recipient you must not copy or distribute it. If you have received this email in error, please notify the sender and delete the email transmission immediately.

Viruses:- Although we have taken steps to ensure that this email and attachments are free from any virus, we advise that in keeping with good computing practice the recipient should ensure they are actually virus free.

Security Warning:- Please note that this email has been created in the knowledge that internet email is not a 100% secure communications medium. We advise that you understand this lack of security and take any necessary measures when emailing us.

Privacy:- We reserve the right to read any email or attachment entering or leaving our systems from any source without prior notice.

**

CALA Group Limited, Registered in Scotland, Company Number SC326357; CALA 1999 Limited, Registered in Scotland, Company Number SC194813; CALA Management Limited, Registered in Scotland Company Number SC013655; all with Registered Office at Adam House, 5 Mid New Cultins, Edinburgh EH11 4DU

CALA Homes (East) Limited, Registered in Scotland, Company Number SC053746; CALA Homes (West) Limited, Registered in Scotland, Company Number SC222577; CALA Homes (North) Limited, Registered in Scotland, Company Number SC465071; all with Registered Office at Johnstone House, 52-54 Rose Street, Aberdeen AB10 1HA; all Agents of CALA Management Limited

CALA Homes (Thames) Limited, Registered in England, Company Number 02522271; CALA Homes (Midlands) Limited, Registered in England, Company Number 00682410; CALA Homes (Chiltern) Limited, Registered in England, Company Number 09088106; CALA Homes (North Home Counties) Limited, Registered in England, Company Number 08800064, CALA Homes (South Home Counties) Limited, Registered in England, Company Number 08800163; all with Registered Office at CALA House, 54 The Causeway, Staines TW18 3AX; all Agents of CALA Management Limited

Banner Management Limited, Registered in England, Company Number 03351227; Banner Construction Limited, Registered in England, Company Number 01457331; Banner Homes Midlands Limited, Registered in England, Company Number 01091164; Banner Homes Southern Limited, Registered in England, Company Number 01453522; Banner Homes Ventures Limited, Registered in England, Company Number 08026864; Banner Homes Group Limited, Registered in England, Company Number 03647340; Banner Homes Bentley Priory Limited, Registered in England, Company Number 08082535; Banner Homes Central Limited, Registered in England, Company Number 01067052; Banner Developments Limited, Registered in England, Company Number 04046706; Banner Freehold Limited, Registered in England, Company Number 4824344; all with Registered Office at CALA House, 54 The Causeway, Staines TW18 3AX