

The Planning Department
Mid Sussex District Council
Oaklands Road
Haywards Heath
RH16 1SS

20/05/2026

Dear Sir/Madam

Electricity Act 1989 – The Overhead Lines (Exemption) (England & Wales) Regulations 2009

This notice is being given to your Council under The Overhead Lines (Exemption) (England & Wales) Regulation 2009.

Under this exemption, your Authority is required to determine, within 6 weeks of receipt of this notice, whether it is considered that the proposal is likely to have a significant adverse effect on the environment.

The works associated with this proposal will commence on site on or after the expiry of the required six weeks notice, unless it becomes necessary to apply to the Secretary of State for Trade and Industry for his consent.

Particulars of proposal:

Location: West Hoathly Brickworks, Hamsey Road, Sharpthorne, RH19 4PA

Plan No: MU4835-L001-REV03 / MU4835-E001-REV07-APP

Details of proposal: Downing and relocation of overhead HV pole. UKPN to complete 1x 11kV HV pole termination at new terminal pole following the diversion of pole 614327 for the establishment of a new IDNO substation to connect a new load.

Proposal is to connect the new substation into the 11 feeder from East Grinstead 33/11kV primary as a teed connection at diverted HV pole 614327. Please see electrical design and legal plan to follow.

Yours faithfully,

The Land Rights Department
landrights@cious.co.uk
07442 919536