

From: David Hutchison <david.hutchison@btinternet.com>
Sent: 22 September 2025 15:26:10 UTC+01:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Subject: Re: 2025.09.03 DM/25/0579 - Hammonds Mill Farm London Road Hassocks
West Sussex BN6 9NB

Hi Anna,

Thank you for the further update.

I can arrange a letter from the Applicant who is also the owner of the 93 acre Hammonds Mill Farm to confirm these details, or will an email from me, as their agent for the application and also their representative on Hammonds Mill Farm in general, confirming their agreement to these details, be acceptable.

All the best.

David

David Hutchison B Arch PG Dio TP
Agent
Sent from my iPhone

On 22 Sep 2025, at 13:28, Anna Tidey <anna.tidey@midsussex.gov.uk> wrote:

Submit your planning application online.
<http://www.planningportal.gov.uk>

Anna Tidey BA(Hons) MPhil MRTPI
Planning Officer
Development Management

Tel: +44 (0)1444 477342
anna.tidey@midsussex.gov.uk <http://www.midsussex.gov.uk>

<image002.png>

Working together for a Better Mid Sussex.



- SAVE A TREE Only print this email if absolutely necessary.

Dear David

Thank you for your email of 15.09.2025, attached. I note the Drainage Team comments of 03.09.2025, see below. Within these comments they request **evidence that permission has been obtained to connect to the treatment plant, that it is adequately sized to take the additional flows and a foul water maintenance and management plan which identifies responsible parties for the lifetime of the dwellings will be required for the shared system.**

Please can you confirm each of these details for me? Once I have this confirmed I will be able to provide a date for the Extension of time and then make my recommendation.

Kind regards

Anna

From: drainage <drainage@midsussex.gov.uk>

Sent: 03 September 2025 20:47

To: Anna Tidey <anna.tidey@midsussex.gov.uk>

Cc: drainage <drainage@midsussex.gov.uk>

Subject: 2025.09.03 DM/25/0579 - Hammonds Mill Farm London Road Hassocks
West Sussex BN6 9NB

Dear Anna,

Thank you for reconsulting the Flood Risk and Drainage Team on the above application. We have reviewed the FLOOD RISK ASSESSMENT and DRAINAGE STRATEGY RESPONSE (2) to MSDC Flood Risk and Drainage Team Further Comments dated 16 July 2025 by DJH. The applicant has provided sufficient information for us to remove our objection.

Fluvial Flood Risk

Revised Finished Floor Level (Barns 3 and 4):

The proposed finished floor levels (FFLs) for Barn 3 and 4 (Dwellings 3 and 4) are now proposed at 27.75mAOD based on Node 364 levels, with EA email confirmation. This will provide a FFL ~890mm above 1:100+35%CC and 690mm above 1:100+105%CC which is deemed acceptable

Confirmation of No Built Footprint or Land Raising:

The applicant has confirmed there will be no additional land raising or additional built footprint as part of the development which is deemed acceptable

Assessment of Unmodelled Watercourses:

The applicant has proposed no alterations to the roof arrangement or layout is proposed and although gutters and downpipes will be replaced, downpipes positions and connections to the existing surface water drainage will not be altered. The existing surface water drains will be jetted and a CCTV survey undertaken including the brick culvert, the drain under the infilled mill pond and the drain from the surface water outfall to the north of Barns 1 and 2 which is deemed acceptable. Evidence of this will be required at the Discharge Condition stage.

Surface Water Flood Risk:

The applicant has demonstrated that no built development will occur within the 1:100 + climate change surface water flood extent and there are no obstructions to the existing flow paths. The FFL's for Barns 1 and 2 will be raised to 29.80m AOD (905mm above ground levels). 600mm flood mitigation above predicted surface water flood depths will be provided which is deemed acceptable.

Pedestrian Escape Route Plan:

Safe escape has been demonstrated for both the fluvial and surface water flood risk to Jane Murray Way (>33.5m AOD) via a public footpath/farm track which heads north of the development which is deemed acceptable.

Surface Water Drainage:

It is proposed that surface water from Barns 3 and 4 will utilise the existing drainage arrangements, while Barns 1 and 2 will discharge to the existing culvert via a mill pond which is to be reinstated and a flow control chamber.

Foul Water Drainage:

As a shared package treatment plant is proposed which is located outside the application boundary, we would expect the applicant to provide evidence that permission has been obtained to connect to the treatment plant, that it is adequately sized to take the additional flows and a foul water maintenance and management plan which identifies responsible parties for the lifetime of the dwellings will be required for the shared system.

We would advise the applicant that any new foul water package treatment plant should be located outside of any modelled flood extents and be located a minimum of 5m from any watercourse/ditch. The system will need to either meet with the Environment Agency's General Binding Rules for package treatment plants, or an Environmental Permit will be required from the Environment Agency. We would also advise that any new outfall(s) into the watercourses/ditches on this site will require Ordinary Watercourse Consent from West Sussex Lead Local Flood Authority.

Ordinary Watercourse Consent

The applicant is advised that if any new development (including construction activities) is to take place within 5 metres of any drain or watercourse. It is important that Ordinary Watercourse Consent (OWC) is fully obtained before works are undertaken near this watercourse. It is important to understand that this Planning consultation deals with the flood risk impact of the proposed development, but the OWC will deal with the impact of

the watercourse alteration. So, whilst the OWC is not a Planning matter, it will need to run alongside this application. Details for OWC are in the advice sections of this consultation. OWC application: <https://www.westsussex.gov.uk/fire-emergencies-and-crime/dealing-with-extremeweather/dealing-withflooding/flood-risk-management/ordinary-watercourse-land-drainage-consent/>

Condition Recommendations

FLOOD RISK AWARENESS

No building shall be marketed, sold, or occupied until a flood risk report has been produced (to be provided to all prospective buyers and included within the buyers pack) and approved in writing by the local planning authority. This flood risk report shall need to include details and images of the modelled flood extents, expected frequency of flooding, the safe escape route, the flood mitigation measures included within the development and highlight landowner riparian rights and responsibilities

Reason: To ensure all new landowners are aware of the flood risk posed to the site, how they can safely escape and their riparian rights and responsibilities for any ditch/watercourse on the boundary of their land under The Land Drainage Act 1991

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.

<mime-attachment>