

From: Emily Wade <Emily.Wade@midsussex.gov.uk>
Sent: 18 May 2026 10:56:25 UTC+01:00
To: "Stefan Galyas" <Stefan.Galyas@midsussex.gov.uk>
Subject: DM/26/0883 Ockenden Garden Lodge

Hi Stefan

Comments on the above discharge of conditions application.

Condition 3: Cladding to garage doors infill

The proposed Cedral cladding is a fibre cement product which will not usually be acceptable in the context of a Conservation Area, or within the setting of a listed building. We would expect instead to see painted timber.

Condition 4: New windows and doors

With respect to the proposed windows and external bifold doors, these appear to be uPVC, which is not a material which is normally acceptable in a Conservation Area, or setting of a listed building. The doors also appear to include prominent trickle vents, which would be regarded as poor detailing. I would suggest the windows are amended to show painted timber windows of an appropriate design, and the doors to painted timber or metal framing, all with concealed vents, if these are required.

These points (regarding the materials to the cladding, windows and doors) were also made in my original comments on the approved planning application.

Thanks,

Emily

Please note that this advice is given at Officer level only and is without prejudice to the formal decision of the District Council.

Submit your planning application online.
<http://www.planningportal.gov.uk>

Emily Wade Ma MSc
Conservation Officer
Planning Services
Tel: +44 (0)1444 477385
emily.wade@midsussex.gov.uk <http://www.midsussex.gov.uk>

The
Electoral
Commission

You now need
photo ID to
vote at a
polling station

No ID? You can apply for free voter ID

Find out more at

electoralcommission.org.uk/voterID

or call 0800 328 0280