

From: drainage <drainage@midsussex.gov.uk>
Sent: 10 January 2025 16:36:30 UTC+00:00
To: "Andrew Horrell" <Andrew.Horrell@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2025.01.10 Re: -DM/24/2819 - 32 Wood Ride Haywards Heath West Sussex RH16 4NJ

Dear Andrew,

Please see our response below for the above application:

The Flood Risk and Drainage Team have reviewed the information submitted in support of this application and can provide the following comments.

Subject to the extension finished floor levels set no lower than existing and the resistance and resilience measures suggested as per the Aegaea Flood Risk Assessment dated 02/01/2024, we have no objection to this development on flood risk grounds.

Drainage should be managed via Building Regulations and Building Control, as necessary.

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk