



Mid Sussex District Council
Oaklands
Oaklands Road
Haywards Heath
West Sussex
RH16 1SS

Your ref
DM/24/3088

Our ref
DSA000040288

Date
21/01/2025

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Demolition of existing garage, removal of existing box dormer, rationalisation of all above-ground external mounted foul surface drainage pipes, construction of two storey side front and rear extension, single storey rear extension, new loft conversion with rear dormers and detached double garage together with all associated internal and external alterations).

Site: Bramham Moor Tylers Green Cuckfield Haywards Heath.

Thank you for your correspondence dated the 15th of January 2025, please see our comments below regarding the above application.

Insufficient Information provided

The applicant has not provided details of the proposed means of disposal of foul/surface water drainage from the site. Southern Water is unable to comment fully on this Planning Consultation until such time as the relevant information is provided.

Condition: Construction of the development shall not commence until details of the proposed means of foul/surface water drainage disposal have been submitted to and approved in writing by the Local Planning Authority in consultation with Southern Water.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
southernwater.co.uk/developing-building/planning-your-development