

WEST SUSSEX COUNTY COUNCIL CONSULTATION

TO:	Mid Sussex District Council FAO: Deborah Lynn
FROM:	WSSC – Highways Authority
DATE:	7 September 2026
LOCATION:	Timbers, Cansiron Lane, East Grinstead, RH19 3SE
SUBJECT:	DM/26/2027 Proposed two storey side and rear extension.
DATE OF SITE VISIT:	n/a
RECOMMENDATION:	Advice

This application has been dealt with in accordance with the Development Control Scheme protocol for small scale proposals.

This application is for a proposed two storey side and rear extension. The site is located on Cansiron Lane, an unclassified road subject to a speed restriction of 30 mph.

There are no proposed changes to the existing access arrangements. The proposed development is not anticipated to give rise to a material intensification of use of the existing access point.

A single-bay garage will be lost as part of the proposals. However, it should be noted that the existing garage does not meet the minimum internal specifications for single-bay garages of 3m x 6m as outlined in Manual for Streets (MfS). Therefore, the LHA would not consider the existing garage for parking provision, as it is likely too small to accommodate modern sized cars. It is not unreasonable for the LHA to assume the existing garage may be being used for other purposes, such as storage.

As such, no concerns are raised regarding loss of existing parking provision. An existing driveway is to be retained with provision for at least two cars and garage/car port.

In summary, the LHA does not consider that this proposal would have an unacceptable impact on highway safety or result in 'severe' cumulative impacts on the operation of the highway network, therefore is not contrary to the National Planning Policy Framework (paragraph 116), and that there are no transport grounds to resist the proposal.

Liz Corcoran
West Sussex County Council – Planning Services