

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 10 February 2025 12:07:23 UTC+00:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: Large Development Hydrant Condition - DC/25/0015 Land West of Turners Hill Road & South of Huntsland, Turners Hill Road, Crawley Down
Attachments: LDHC - DC250015 - West of Turners Hill Road & South of Huntsland, Turners Hill Road, Crawley Down.docx

FAO: Steven King

Dear Steven,

Please find attached a planning condition for application no. DM/25/0015 for the requirement of additional fire hydrant(s) for the proposed development. This is to ensure that all dwellings on the proposed site are within 150 metres of a fire hydrant for the supply of water for firefighting.

Evidence will also be required that Fire Service vehicle access meets with the requirements identified in Approved Document B Volume 1 2019 Edition: B5 Section 13, including Table 13.1 and diagram 13.1.

Regards

Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his 

[Click here to find out why we use pronouns in our signatures](#)



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
