

From: Emma Rivett <Emma.Rivett@midsussex.gov.uk>
Sent: 10 July 2026 12:18:26 UTC+01:00
To: "Andy Watt" <Andy.Watt@midsussex.gov.uk>
Subject: DM/26/1477 - Land Adjacent to Nightingales, The Street, Bolney, RH17 5PJ

Dear Andy,

I have reviewed the Arboricultural Impact Assessment (AIA), Arboricultural Survey, Arboricultural Method Statement (AMS), and Tree Protection Plan (TPP), for this proposal and have no objection. The only comment I have is that the replanting should not occur underneath the sycamore, T1, as it appears on the drawing no. Arbtech AIA 01, as the sycamore will grow back and cast shade over new plantings.

Please condition adherence to the AIA, AMS, and TPP.

Kind regards

Emma

Emma Rivett
Assistant Tree Officer-Development Management
www.midsussex.gov.uk

Working together for a better Mid Sussex