

From: Emily Wade <Emily.Wade@midsussex.gov.uk>
Sent: 24 September 2025 16:53:35 UTC+01:00
To: "Andrew Horrell" <Andrew.Horrell@midsussex.gov.uk>
Subject: DM/25/2213 5 Franklands Village

Hi Andrew,

Comments on the above discharge of condition application.

Further information is required:

- Can the applicant please provide details of the materials to the existing windows to the house? I can't find this anywhere in the current or original application.
- What is the proposed location of the solid doors, as these do not appear to be shown on the approved plans? We would not normally accept composite doors within a Conservation Area, unless these are already present to the house.
- Do the proposed windows/French windows/bifold doors include trickle vents? Where these are necessary, they should be concealed within the frames of the units. Prominent trickle vents will not be accepted. Details of this should be provided.

Thanks,

Emily

Please note that this advice is given at Officer level only and is without prejudice to the formal decision of the District Council.

Submit your planning application online.
<http://www.planningportal.gov.uk>

Emily Wade Ma MSc
Conservation Officer
Planning Services
Tel: +44 (0)1444 477385
emily.wade@midsussex.gov.uk <http://www.midsussex.gov.uk>



No ID? You can apply for free voter ID
Find out more at
electoralcommission.org.uk/voterID
or call 0800 328 0280