

From: Susan Dubberley
Sent: 02 September 2026 12:41:03 UTC+01:00
To: "Susan Dubberley" <Susan.Dubberley@midsussex.gov.uk>
Subject: FW: RE: DM/26/1524 Aldi Haywards Heath

Good afternoon Sue,

Apologies, I have been back and checked this site and there is a fire hydrant within 90m of the store entrance and there looks to be suitable turning facility for a fire appliance to turn and make their exit, so the Approved Document B (AD-B) Volume 2: B5 requirements have been met and no concerns identified. No further actions required for the supply of water for firefighting and access for a fire appliance.

Regards
Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West

From: Susan Dubberley <Susan.Dubberley@midsussex.gov.uk>
Sent: 26 August 2026 12:43
To: FRS Water and Access <frs.waterandaccess@westsussex.gov.uk>
Subject: FW: RE: DM/26/1524 Aldi Haywards Heath

****EXTERNAL****