



Mid Sussex District Council
Planning Department

Your ref
DM/25/1294

Our ref

DSA000044528

Date
4th June 2025

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Construction of a single-storey conservatory extension to the west-facing elevation, and a small Kitchen extension to the east elevation. Enhancements to the existing fenestration to include replacement balcony balustrading, window replacement and refurbishments, and a replacement rear door. Internal alterations to all levels. Internal refurbishment works to the existing Annexe, replacement of the existing external Annexe staircase, and replacement of existing Annexe windows. Erection of a traditional Greenhouse structure within the garden. Associated hard and soft landscaping works to comprise new paved terracing, steps, paths, and remodelling of the existing parking area. Replacement driveway entrance gates.

Site: : Idlehurst Birchgrove Road Horsted Keynes Haywards Heath

Following the weekly list sent on 27th May 2025, Southern Water has determined that the flow rate for the above site will remain consistent, so capacity is not an issue and no Southern Water assets will be affected. Therefore, Southern Water has no objections to this proposal.

Please note surface water should not be disposed of into a public foul sewer and must comply with the Hierarchy of H3 of the Building Regulations. For more details, refer to the Drainage and Waste Disposal: Approved Document H on the GOV.UK website.

Any new connections to the public sewerage system will require a New Sewer Connection application (also known as a Section 106) to be submitted and approved by Southern Water.

Due to legislative changes effective from 1st October 2011 regarding the ownership of sewers, it is possible that some previously private sewers, now deemed public, could be crossing the above property and may not be shown on Southern Water records. Therefore, if any additional sewers are discovered during construction, an investigation will be required to determine their condition, the number of properties served, and potential access methods before any further work can proceed on site.



For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team

southernwater.co.uk/developing-building/planning-your-development