



Mid Sussex District Council  
Oaklands  
Oaklands Road  
Haywards Heath  
West Sussex  
RH16 1SS

**Your ref**  
DM/25/1205

**Our ref**  
DSA000048211

**Date**  
13<sup>th</sup> of October 2025

**Contact**  
Tel 0330 303 0119

Dear Sir/Madam,

**Proposal:** Proposal to erect six above ground columbariums for ashes interments and install a path in front of the columbarium.

**Site:** Mount Noddy Cemetery Blackwell Road East Grinstead West Sussex.

Thank you for your correspondence, please see our comments below regarding the above application.

#### **Proposed soakaways**

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development. No new soakaways should be located within 5 metres of a public or adoptable gravity sewer, rising main or water main.

No Soakaways should be connected to the public surface water sewer.

#### **Foul Drainage is not applicable for this development.**

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)

Website: [southernwater.co.uk](https://southernwater.co.uk) or by email at: [SouthernWaterPlanning@southernwater.co.uk](mailto:SouthernWaterPlanning@southernwater.co.uk)

Yours faithfully,

Future Growth Planning Team  
[southernwater.co.uk/developing-building/planning-your-development](https://southernwater.co.uk/developing-building/planning-your-development)