

From: drainage <drainage@midsussex.gov.uk>
Sent: 11 September 2026 14:26:49 UTC+01:00
To: "Joanne Fisher" <Joanne.Fisher@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2026.09.11 Re: DM/26/0846 - Crabbet Park Equestrian Centre Turners Hill Road
Turners Hill Crawley West Sussex RH10 4ST

Dear Joanne,

Our engineers apologise for the delay in response. Upon further review of information provided for DM/26/0846, it appears that the runoff from the trafficked areas do not pass through the SuDS planters. Therefore, sufficient pollution mitigation in accordance with the CIRIA SuDS Manual has not been demonstrated.

Please could you request further submission from the applicant for us to be able to review and comment further.

Should you have any questions of course please do email to advise and we will support,

Best Wishes

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk