

From: [REDACTED]
Sent: 15 January 2026 19:59
To: Jessica Szollosi <Jessica.Szollosi@midsussex.gov.uk>; [REDACTED]
Subject: Fwd: 2 Oak Cottages, Crawley Down - DM/25/2675

You don't often get email from [REDACTED] [Learn why this is important](#)

Hi Jessica

Please see email and drawings attached and I hope this is sufficient to your requirements

With regard to the hardstanding, the area has been constructed using permeable block paving laid over a compacted sub-base in accordance with standard installation practices.

The hardstanding comprises concrete block pavers laid on a sharp sand bedding layer over a graded granular sub-base. The design allows surface water to drain naturally through the joints and construction layers below.

Surface water drainage has been designed to prevent runoff onto the public highway or neighbouring land. Rainwater is directed to permeable ground within the site and is allowed to infiltrate naturally. No surface water from the hardstanding is connected to the main sewer or discharged off-site.

Should you require any further clarification or supporting information, please do not hesitate to contact me.

Kindly regards

[REDACTED]