

 BRE Sunlight Provision Assessment (Annuual Probable Sunlight Hours) Project: 8 Ockley Road Date of Analysis: 13/08/2025														
			Individual Window Assessment						Whole Room Assessment					
Floor Ref.	Room Ref.	Window Ref.	Annual	Sunlight Retained	Meets BRE Guidance	Winter	Sunlight Retained	Meets BRE Criteria	Total Suns per Room Annual	Sunlight Retained	Meets BRE Guidance	Total Suns per Room Winter	Sunlight Retained	Meets BRE Guidance
10 Ockley Lane														
Ground	R1 Living	W1	Existing Proposed	44.00 36.00	82%	YES	0.00 0.00	100%	N/A					
		W2	Existing Proposed	37.00 26.00	70%	YES	0.00 0.00	100%	N/A					
	R2 Kitchen/ Dining	W3	Existing Proposed	41.00 28.00	68%	YES	0.00 0.00	100%	N/A					
		W4	Existing Proposed	43.00 36.00	84%	YES	0.00 0.00	100%	N/A	51.00 42.00	82%	YES	0.00 0.00	100% YES
First	R1 Bedroom	W1	Existing Proposed	71.00 69.00	97%	YES	21.00 19.00	90%	YES					
		W2	Existing Proposed	71.00 65.00	92%	YES	20.00 14.00	70%	YES	71.00 69.00	97%	YES	21.00 19.00	90% YES
	R2 Ensuite?	W3	Existing Proposed	78.00 67.00	86%	YES	22.00 11.00	50%	YES					
		W4	Existing Proposed	78.00 67.00	86%	YES	22.00 11.00	50%	YES	71.00 65.00	92%	YES	20.00 14.00	70% YES
First	R3 Bathroom	W1	Existing Proposed	78.00 67.00	86%	YES	22.00 11.00	50%	YES					
		W2	Existing Proposed	78.00 67.00	86%	YES	22.00 11.00	50%	YES	78.00 67.00	86%	YES	22.00 11.00	50% YES
	R4 Bedroom	W1	Existing Proposed	78.00 67.00	86%	YES	22.00 11.00	50%	YES					
		W2	Existing Proposed	78.00 67.00	86%	YES	22.00 11.00	50%	YES	78.00 67.00	86%	YES	22.00 11.00	50% YES