

Ground Floor
Northleigh
County Hall
Chichester
West Sussex
PO19 1RH



Lead Local Flood Authority

Date 20th April 2026

Steven King
Development Control
Mid Sussex District Council
Oaklands Road
Haywards Heath
West Sussex
RH16 1SS

Dear Steven,

**RE: DM/26/0577 – Land West Of Turners Hill Road And North Of Huntsland
Including Hurst Farm, Turners Hill Road, Crawley Down, West Sussex**

Thank you for your reconsultation on the above site, received on 30th March 2026. We have reviewed the application as submitted and wish to make the following comments.

Following the submission of the additional information, our concerns have been adequately addressed. We therefore have **no objection, subject to conditions**:

Condition 1:

Prior to commencement of the development, detailed designs of a surface water drainage scheme shall be submitted to and agreed with the Local Planning Authority. This shall be in accordance with the approved Flood Risk Assessment, Ramboll, 27.02.2026, Version 2.0 and Drainage Strategy by Ramboll, 27.02.2026, Version 3.0. The design shall follow the NPPF, PPG Flood risk and coastal change and National Standards for SuDS. The submitted details shall include:

1. Surface water runoff rates will be attenuated to the rates and volumes stated within 3.4 of the of the Drainage Strategy.
2. Evidence that the surface water drainage system complies with the National Standards for SuDS for the management of everyday rainfall (interception).
3. Details of all existing and proposed watercourses and sewers, including any proposed discharge points.
4. Provision of surface water attenuation storage, sized and designed to accommodate the volume of water generated in all rainfall events up to and including the critical storm duration for the 3.33% and 1% annual probability rainfall events (both including allowances for climate change). Hydraulic calculations and detailed construction drawings shall be submitted to demonstrate this.
5. Detailed drainage layout plan, which corresponds with the hydraulic calculations.

6. An exceedance flow routing plan demonstrating no increase in surface water flood risk off site. The plan must include proposed levels and flow directions.
7. Evidence that the surface water drainage system meets Standard 4-6 of the National Standards for SuDS.
8. Construction method statement for the surface water drainage system and any ordinary watercourses within or adjacent to the site.
9. Site-specific maintenance and management plan for all elements of the surface water drainage system and any ordinary watercourses/culverts within the development.
10. Finished ground floor levels of residential properties are a minimum of 300mm above expected flood levels of all sources of flooding (including the ordinary watercourses, SuDS features and within any proposed drainage scheme) or 150mm above ground level, whichever is the more precautionary.

Reason: To prevent flooding in accordance with National Planning Policy Framework paragraphs 181,182 and 187 plus National SuDS Standards 1 to 7, by ensuring the satisfactory management of local sources of flooding surface water flow paths, storage and disposal of surface water from the site in a range of rainfall events and ensuring the SuDS proposed operates as designed for the lifetime of the development.

Condition 2:

Upon completion of the surface water drainage scheme (or phase) and prior to the first occupation of the development (or phase), a detailed verification report, (appended with substantiating evidence demonstrating the approved construction details and specifications have been implemented in accordance with the surface water drainage scheme), has been submitted to and approved (in writing) by the Local Planning Authority. The survey and report shall demonstrate that the surface water drainage system has been constructed in accordance with the details approved and shall include as a minimum.

1. CCTV survey of underground structures,
2. A full set of "as built" drawings highlighting any minor changes to the approved drawings.
3. Demonstration that vegetation has become established.
4. Photographs of excavations (including soil profiles/horizons) and any installation of any surface water drainage structures and control mechanisms.
5. Where necessary, details of corrective works to be carried out along with a timetable for their completion, shall be included for approval in writing by the Local Planning Authority. Any corrective works required shall be carried out in accordance with the approved timetable and subsequently re-surveyed with the findings submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure that the development achieves a high standard of sustainability and ensure the flood risk is adequately addressed for each new dwelling and not increased in accordance with NPPF and Local Plan Policies of Arun District Council.

Condition 3:

The development hereby approved shall not be occupied until details of the maintenance and management of the Sustainable Drainage Scheme (SuDS) in accordance with

National SuDS Standard 7 have been submitted to and approved in writing by the Local Planning Authority. The drainage scheme shall be implemented prior to the first occupation of the development hereby approved and thereafter managed and maintained in accordance with the approved details in perpetuity. The Local Planning Authority shall be granted access to inspect the sustainable drainage scheme for the lifetime of the development. The details of the network in addition to those listed in SuDS Standard 7 to be submitted for approval shall include:

1. A timetable for its implementation.
2. Details of SuDS feature and connecting drainage structures and maintenance requirement for each aspect including a non-technical labelled drawing showing where they are located and how to access them.
3. A management and maintenance plan for the lifetime of the development which shall include the arrangements for adoption by any public body or statutory undertaker, or any other arrangements to secure the operation of the sustainable drainage scheme throughout its lifetime. This will include the name and contact details of any appointed management company.

Reason: To ensure that the development achieves a high standard of sustainability and ensure the flood risk is adequately addressed for each new dwelling and not increased in accordance with NPPF and Local Plan Policies of Arun District Council.

Informative:

Erection of flow control structures or any culverting of an ordinary watercourse requires consent from the appropriate authority, which in this instance is West Sussex Lead Local Flood Authority. It is advised to discuss proposals for any works at an early stage of proposals. Further details can be found here: [Ordinary watercourse land drainage consent - West Sussex County Council](#)

Please note: these suggested conditions are different to the other sites referenced by the applicant in order to reflect the National Standards for SuDS. We will shortly be releasing guidance on what we expect to see when discharging these suggested conditions. This will be hosted on our website.

Yours sincerely,

Eleanor Read
Flood Risk Management Team
FRM@westsussex.gov.uk

Annex:

The following documents have been reviewed:

- Flood Risk Assessment, Ramboll, 27.02.2026, Version 2.0
- Drainage Strategy by Ramboll, 27.02.2026, Version 3.0