

From: drainage <drainage@midsussex.gov.uk>
Sent: 11 May 2026 10:37:08 UTC+01:00
To: "Andrew Clarke" <Andrew.Clarke@midsussex.gov.uk>
Cc: "drainage" <drainage@midsussex.gov.uk>
Subject: 2026.05.11 RE: DM/25/2123 - Cuckfield Golf Course Staplefield Road Cuckfield Haywards Heath West Sussex RH17 5HY

Dear Andrew,

Apologies for my lack of reply to your emails of last week, I was on leave, returning today. The Flood Risk and Drainage Engineers reviewed the updated information and have advised as below:

It has now been confirmed that there will be no new hardstanding or permeable areas. Any excess runoff from the existing MOT Type 2 surface will be directed into the proposed attenuation system.

As Type 2 is not considered permeable, an allowance should be made within the attenuation design to ensure the system is sufficiently sized.

Upon receipt of this information, we will be able to comment further. Any query of course do let us know.

Best Wishes
Emma

Flood Risk and Drainage Team
Estate Services and Building Control
Mid Sussex District Council
drainage@midsussex.gov.uk