

**From:** drainage <drainage@midsussex.gov.uk>  
**Sent:** 02 October 2025 08:25:16 UTC+01:00  
**To:** "Katherine Williams" <Katherine.Williams@midsussex.gov.uk>  
**Cc:** "drainage" <drainage@midsussex.gov.uk>  
**Subject:** 2025.10.02 Re: DM/25/0961 - 201 Junction Road Burgess Hill

Good Morning Katherine,

The Engineers have reviewed the above and have asked if the applicant could provide a copy of the infiltration testing results. They were carried out at the site and are referred to in the left hand comments (The existing ground offers good porosity tests which were carried out by the client offering an average design rate of  $1.35 \times 10^{-5} \text{ m/s}$  ) on the Site Plan - Proposed Foul and Storm Water Drainage Plan DWG No & Rev 100 P4.

The Engineers would have expected this to be carried out using the formal BRE365 methodology along with a plan of the pit location, including photographs of the process.

Once we are in receipt of this additional information, we should be able to respond quite quickly. Any questions of course let us know,

Best Wishes  
Emma

**Flood Risk and Drainage Team  
Estate Services and Building Control  
Mid Sussex District Council  
[drainage@midsussex.gov.uk](mailto:drainage@midsussex.gov.uk)**