

From: Irene Fletcher <Irene.Fletcher@midsussex.gov.uk>
Sent: 01 October 2026 09:56:45 UTC+01:00
To: "Catherine Cardin" <Catherine.Cardin@midsussex.gov.uk>
Subject: DM/26/1716

Hi Catherine,

Apologies for the delayed response.

I would normally have expected a full AIA to accompany the application, along with a tree survey, however, I have looked at your photographs and, with the exception of the cedar, none of the other trees would appear to provide a constraint to development. In this case, therefore, I will not request these details.

However, whilst the tree protection plan does show RPAs, it does not show the tree protection details, which should also include the storage exclusion areas.

Could the plan be amended to show these details ?

Thanks,

Irene

Irene Fletcher
Tree Officer
Development Management
Mid Sussex District Council
(Mon – Thurs)
www.midsussex.gov.uk