

RE: DM/26/1648 55 College Lane Air Source Heat Pump

 Summarise



Adam Dracott

To  Stefan Galyas

Retention Policy Default 3 year delete (3 years)

Expires on 10/09/2029



 Reply

 Reply All

 Forward





Fri 11/09/2026 12:57

Hi Stefan

I have looked at the assessment which has been carried out in accordance with MCS 020 and I am satisfied that it meets the 37dBA standard. So the noise impact is low. I have therefore no objections to the proposal.

Regards

Adam