

From: pep b <pep8@hotmail.com>
Sent: 04 June 2025 19:21:32 UTC+01:00
To: "Rachel Richardson" <Rachel.Richardson@midsussex.gov.uk>; "Anemone Interiors" <soho@anemoneinteriors.co.uk>
Subject: Re: DM/24/1879 and 2406 2 Church Cottages, Street Lane, Ardingly
Attachments: proposed elevations without galzing bar.pdf, proposed section window item 10.pdf

Hi Rachel,

Thank you for your reply.

Please see attached amendments to the proposed drawings.

please let me know if you need anything else.

Kind Regards

Giuseppe & Lia Briamonte

From: Rachel Richardson <Rachel.Richardson@midsussex.gov.uk>

Sent: 02 June 2025 10:37

To: pep b <pep8@hotmail.com>

Subject: FW: DM/24/1879 and 2406 2 Church Cottages, Street Lane, Ardingly

Dear Giuseppe,

Please see Emily's comments below.

Emily has asked that the central, horizontal glazing bar be removed and the drawings amended to reflect this. It will mean amending all of the proposed detailed drawings and proposed elevations. Emily has suggested below that I could grant permission and add a planning condition requesting this detail once permission is granted but I think it would be better to do this now and as part of the live application.

As such, please can you revise both applications accordingly. Once I have received the amended drawings I will write up the applications recommending that permission be granted. I won't re consult given that this is a request as a result of Emily's comments only.

Kind regards,

Rachel.

Rachel Richardson Bsc (Hons) DIP TP MRTPI

Senior Planning Officer

Development Management

www.midsussex.gov.uk

01444 477 224

Please note I work part-time (usually over Monday to Thursday) and from home Monday to Wednesday.

From: Emily Wade <Emily.Wade@midsussex.gov.uk>
Sent: 23 May 2025 08:12
To: Rachel Richardson <Rachel.Richardson@midsussex.gov.uk>
Subject: DM/24/1879 and 2406 2 Church Cottages, Street Lane, Ardingly

Hi Rachel

Further comments on the above applications following the receipt of further plans and an updated heritage statement.

On the basis of the information within the heritage statement, I remain of the opinion that the replacement of the windows is not contentious in principle, as the existing units do not appear to be of any great age or interest. I also consider that the inclusion of slim-line double glazing will be in principle acceptable, as it would appear that this can be accomplished without a detrimental impact on the proportions or profile of the framing. However, the accurate plans now before us confirm that the proposal includes the introduction of a horizontal glazing or sash bar subdividing the casements into two vertically. In other circumstances, this might not be regarded as contentious but here it would mean that the windows to 2 Church Cottages would not remain consistent in appearance with those to its attached neighbour at no. 1. The consistency of elevational treatment is one of the defining characteristics of the cottage pair. I would therefore recommend that the application is revised to omit the glazing bar, so that the glazing pattern of the new windows matched the existing to this property and the neighbouring cottage.

I would be happy for this to be achieved by an amending condition if this is considered appropriate, e.g. 'The window design shall be amended to omit the horizontal sash or glazing bar in all cases. Prior to the commencement of works a detailed typical elevation to show this amendment shall be submitted to and approved in writing by the District Council. The works shall then be carried out according to these details. ', with the standard reason.

Thanks,

Emily

Please note that this advice is given at Officer level only and is without prejudice to the formal decision of the District Council.

Submit your planning application online.
<http://www.planningportal.gov.uk>

Emily Wade Ma MSc
Conservation Officer
Planning Services
Tel: +44 (0)1444 477385
emily.wade@midsussex.gov.uk <http://www.midsussex.gov.uk>

The
Electoral
Commission

You now need
photo ID to
vote at a
polling station

No ID? You can apply for free voter ID

Find out more at

electoralcommission.org.uk/voterID

or call 0800 328 0280

The information contained in this email may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information contained in this email is legally exempt from disclosure, we cannot guarantee that we will not provide the whole or part of this email to a third party making a request for information about the subject matter of this email. This email and any attachments may contain confidential information and is intended only to be seen and used by the named addressees. If you are not the named addressee, any use, disclosure, copying, alteration or forwarding of this email and its attachments is unauthorised. If you have received this email in error please notify the sender immediately by email or by calling +44 (0) 1444 458 166 and remove this email and its attachments from your system. The views expressed within this email and any attachments are not necessarily the views or policies of Mid Sussex District Council. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks before accessing this email and any attachments. Except where required by law, we shall not be responsible for any damage, loss or liability of any kind suffered in connection with this email and any attachments, or which may result from reliance on the contents of this email and any attachments.