

Site Address: Perrymount Road, Haywards Heath	RISK ASSESSMENT FOR CFA PILING		
Contract Number: 1812	Revision:	Date: 17th February 2026	

Key to Risk Rating:		Severity (S)				
		1	2	3	4	5
Likelihood (L)	1	1	2	3	4	5
	2	2	4	6	8	10
	3	3	6	9	12	15
	4	4	8	12	16	20
	5	5	10	15	20	25

Likelihood (L)		Severity (S)	
1	Very Unlikely	1	Minor injury, no lost time, no damage
2	Unlikely	2	Minor injury, less than or equal to 3 days lost time, minor damage
3	Likely	3	Reportable injury, 3+ days lost time, temporary disruption to operations
4	Very Likely	4	Major injury, damage, theft
5	Certain	5	Fatality, major damage, industry disruption
Risk Rating (RR) = Likelihood (L) x Severity (S)			

Item	Activity	Hazards/Risks Identified	Risk Rating			Control Measures	Residual Risk			Responsibility	Monitoring Responsibility
			S	L	RR		S	L	RR		

	GENERAL SITE SAFETY	Lack of General Awareness	3	3	9	- All operatives to be inducted onto site. - All operatives to have relevant training. - Revisions to Safety Risk Assessments are to be cascaded down by Toolbox talks	3	1	3	All Operatives	Site Foreman
	GENERAL SITE SAFETY	Lack of personal protection	3	3	9	- All operatives to wear the correct PPE, ie Safety Helmet, Safety Footwear, Hi-Visibility Vest, Gloves, Light Eye Protection, Flame Proof Overalls. - Wear additional task specific PPE as appropriate.	3	1	3	All Operatives	Site Foreman
	TRANSPORT & DELIVERIES	Movement of delivery vehicles	5	3	15	- Delivery vehicles to be guided by the banksman when on site. - All site operatives to be made aware of vehicle reversing dangers. - Limit vehicle speed.	5	1	5	Banksman	Site Foreman

Site Address: Perrymount Road, Haywards Heath	RISK ASSESSMENT FOR CFA PILING									
Contract Number: 1812	Revision:			Date: 17th February 2026						

Key to Risk Rating:		Severity (S)				
		1	2	3	4	5
Likelihood (L)	1	1	2	3	4	5
	2	2	4	6	8	10
	3	3	6	9	12	15
	4	4	8	12	16	20
	5	5	10	15	20	25

Likelihood (L)		Severity (S)	
1	Very Unlikely	1	Minor injury, no lost time, no damage
2	Unlikely	2	Minor injury, less than or equal to 3 days lost time, minor damage
3	Likely	3	Reportable injury, 3+ days lost time, temporary disruption to operations
4	Very Likely	4	Major injury, damage, theft
5	Certain	5	Fatality, major damage, industry disruption
Risk Rating (RR) = Likelihood (L) x Severity (S)			

Item	Activity	Hazards/Risks Identified	Risk Rating			Control Measures	Residual Risk			Responsibility	Monitoring Responsibility
			S	L	RR		S	L	RR		
	MANUAL HANDLING	Personal injury and injury to bystanders	3	3	9	- Ensure mechanical lifts are used whenever possible and practicable. - Split loads down into smaller/lighter loads whenever possible. - Ensure the ground around the lift is firm and as level as possible. - Check for a clear path and remove trip hazards. - Ensure the area is well lit. - Instruct bystanders to move out of the way. - Always adopt lifting guidance given in Manual Handling toolbox talk.	3	1	3	All piling operatives	Site Foreman

Site Address: Perrymount Road, Heywards Heath		RISK ASSESSMENT FOR CFA PILING									
Contract Number: 1812		Revision:			Date: 17th February 2026						

Key to Risk Rating:		Severity (S)				
		1	2	3	4	5
Likelihood (L)	1	1	2	3	4	5
	2	2	4	6	8	10
	3	3	6	9	12	15
	4	4	8	12	16	20
	5	5	10	15	20	25

Likelihood (L)		Severity (S)	
1	Very Unlikely	1	Minor injury, no lost time, no damage
2	Unlikely	2	Minor injury, less than or equal to 3 days lost time, minor damage
3	Likely	3	Reportable injury, 3+ days lost time, temporary disruption to operations
4	Very Likely	4	Major injury, damage, theft
5	Certain	5	Fatality, major damage, industry disruption
Risk Rating (RR) = Likelihood (L) x Severity (S)			

Item	Activity	Hazards/Risks Identified	Risk Rating			Control Measures	Residual Risk			Responsibility	Monitoring Responsibility
			S	L	RR		S	L	RR		
	LIFTING	Lifting of materials or plant	4	3	12	- Avoid standing beneath suspended loads. - Use the appropriate lifting equipment/slings - Operatives and equipment to hold correct certification.	4	1	4	Foreman & Banksman	Site Foreman
	DRAINS & SERVICES	Interruption of services. Leakage of gas, sewage. Electric shock	3	3	9	- Live services to be identified and clearly marked on site. - Remove, divert, isolate, protect before piling. - Operate permit to dig system.	3	1	3	Principal Contractor	Site Foreman
	WORKING PLATFORM	Safe support of plant & equipment	5	4	20	Concrete piling platform provided.	2	1	2	Principal Contractor	Site Foreman

Site Address: Perrymount Road, Haywards Heath		RISK ASSESSMENT FOR CFA PILING									
Contract Number: 1812		Revision:			Date: 17th February 2026						

Key to Risk Rating:		Severity (S)				
		1	2	3	4	5
Likelihood (L)	1	1	2	3	4	5
	2	2	4	6	8	10
	3	3	6	9	12	15
	4	4	8	12	16	20
	5	5	10	15	20	25

Likelihood (L)		Severity (S)	
1	Very Unlikely	1	Minor injury, no lost time, no damage
2	Unlikely	2	Minor injury, less than or equal to 3 days lost time, minor damage
3	Likely	3	Reportable injury, 3+ days lost time, temporary disruption to operations
4	Very Likely	4	Major injury, damage, theft
5	Certain	5	Fatality, major damage, industry disruption
Risk Rating (RR) = Likelihood (L) x Severity (S)			

Item	Activity	Hazards/Risks Identified	Risk Rating			Control Measures	Residual Risk			Responsibility	Monitoring Responsibility
			S	L	RR		S	L	RR		
	PILING	Personnel working adjacent to piling rig	5	3	15	- All plant movements to be supervised by banksman. - All piling crew and site personnel to be made aware of the slewing, tracking and reversing movements of piling rig. - Only piling operatives and authorised personnel to enter the work area.	5	1	5	Site Foreman	Site Foreman
	PILING	Injuries due to entrapment in rotating augers	5	3	15	3m exclusion zone to be established around front of piling rig. - Banksman / spanner-man to stand away from rig when augers are penetrating or being withdrawn. - Banksman / spanner-man to maintain visual contact with rig operator at all times.	5	1	5	Site Foreman	Site Foreman

Site Address: Perrymount Road, Haywards Heath		RISK ASSESSMENT FOR CFA PILING									
Contract Number: 1812		Revision:			Date: 17th February 2026						

Key to Risk Rating:

		Severity (S)				
		1	2	3	4	5
Likelihood (L)	1	1	2	3	4	5
	2	2	4	6	8	10
	3	3	6	9	12	15
	4	4	8	12	16	20
	5	5	10	15	20	25

Likelihood (L)		Severity (S)	
1	Very Unlikely	1	Minor injury, no lost time, no damage
2	Unlikely	2	Minor injury, less than or equal to 3 days lost time, minor damage
3	Likely	3	Reportable injury, 3+ days lost time, temporary disruption to operations
4	Very Likely	4	Major injury, damage, theft
5	Certain	5	Fatality, major damage, industry disruption

Risk Rating (RR) = Likelihood (L) x Severity (S)

Item	Activity	Hazards/Risks Identified	Risk Rating			Control Measures	Residual Risk			Responsibility	Monitoring Responsibility
			S	L	RR		S	L	RR		
	PILING & CONCRETING	Noise	4	3	12	All operatives to use ear protection when working in areas where noise levels are above acceptable limits.	1	3	3	All piling Operatives	Site Foreman
	PILING & CONCRETING	Environmental Pollution	4	3	12	- Ensure concrete is as specified .. - Designated area or skips for overspill to be provided .	4	1	4	All piling Operatives	Site Foreman

Site Address: Perrymount Road, Haywards Heath		RISK ASSESSMENT FOR CFA PILING									
Contract Number: 1812		Revision:			Date: 17th February 2026						

Key to Risk Rating:

		Severity (S)				
		1	2	3	4	5
Likelihood (L)	1	1	2	3	4	5
	2	2	4	6	8	10
	3	3	6	9	12	15
	4	4	8	12	16	20
	5	5	10	15	20	25

Likelihood (L)		Severity (S)	
1	Very Unlikely	1	Minor injury, no lost time, no damage
2	Unlikely	2	Minor injury, less than or equal to 3 days lost time, minor damage
3	Likely	3	Reportable injury, 3+ days lost time, temporary disruption to operations
4	Very Likely	4	Major injury, damage, theft
5	Certain	5	Fatality, major damage, industry disruption

Risk Rating (RR) = Likelihood (L) x Severity (S)

Item	Activity	Hazards/Risks Identified	Risk Rating			Control Measures	Residual Risk			Responsibility	Monitoring Responsibility
			S	L	RR		S	L	RR		
	CONCRETE		3	5	15	- Consider the positioning of plant to minimise the risk of splashing adjacent personnel, structures, cars, huts, site cabins, pedestrians etc. - Eye protection and gloves to be worn. - Only personnel involved in the task to be in the vicinity of the operation. - A suitable container to be in position at the open end.	3	1	3	Site Foreman	Site Foreman

Site Address: Perrymount Road, Haywards Heath		RISK ASSESSMENT FOR CFA PILING								
Contract Number: 1812		Revision:			Date: 17th February 2026					

Key to Risk Rating:

		Severity (S)				
		1	2	3	4	5
Likelihood (L)	1	1	2	3	4	5
	2	2	4	6	8	10
	3	3	6	9	12	15
	4	4	8	12	16	20
	5	5	10	15	20	25

Likelihood (L)		Severity (S)	
1	Very Unlikely	1	Minor injury, no lost time, no damage
2	Unlikely	2	Minor injury, less than or equal to 3 days lost time, minor damage
3	Likely	3	Reportable injury, 3+ days lost time, temporary disruption to operations
4	Very Likely	4	Major injury, damage, theft
5	Certain	5	Fatality, major damage, industry disruption

Risk Rating (RR) = Likelihood (L) x Severity (S)

Item	Activity	Hazards/Risks Identified	Risk Rating			Control Measures	Residual Risk			Responsibility	Monitoring Responsibility
			S	L	RR		S	L	RR		
	CONCRETE	Concrete splashes to the eyes and skin	3	4	12	- Wear protective eyewear. - Wear gloves when handling grouts and concrete. - Wash off all spills on exposed skin as soon as possible with fresh water.	3	1	3	All Operatives	Site Foreman
	TRIPS AND IMPALEMENT	Injuries to personnel from projecting rebar	3	3	9	- Use protective caps or mound spoil on projections. - All reinforcement to be placed to PPL in order to mitigate any steel projection.	3	1	3	All Operatives	Site Foreman

Site Address: Perrymount Road, Haywards Heath	RISK ASSESSMENT FOR CFA PILING							
Contract Number: 1812	Revision:			Date: 17th February 2026				

Key to Risk Rating:		Severity (S)				
		1	2	3	4	5
Likelihood (L)	1	1	2	3	4	5
	2	2	4	6	8	10
	3	3	6	9	12	15
	4	4	8	12	16	20
	5	5	10	15	20	25

Likelihood (L)		Severity (S)	
1	Very Unlikely	1	Minor injury, no lost time, no damage
2	Unlikely	2	Minor injury, less than or equal to 3 days lost time, minor damage
3	Likely	3	Reportable injury, 3+ days lost time, temporary disruption to operations
4	Very Likely	4	Major injury, damage, theft
5	Certain	5	Fatality, major damage, industry disruption
Risk Rating (RR) = Likelihood (L) x Severity (S)			

Item	Activity	Hazards/Risks Identified	Risk Rating			Control Measures	Residual Risk			Responsibility	Monitoring Responsibility
			S	L	RR		S	L	RR		
	OPERATION OF EXCAVATORS & DUMPERS	Overturning of mobile plant	5	3	15	- All excavator movements to be under the control of banksman. - All plant to have rollover protection and working warning lights fitted. - Seat belts are to be used if fitted. - Riding on plant by passenger is forbidden. - Only tow plant using the correct towing hook and connections	5	1	5	Banksman & all other operatives associated with the piling works	Site Foreman
	PLANT MAINTENANCE	Contact with fuels, oils, lubricants and greases	2	3	6	- Follow COSHH guidance. - Tool box talks to be carried out to highlight risk. - Avoid prolonged exposure or immersion. - Wash off all spills on exposed skin as soon as possible.	2	1	2	All piling operatives	Site Foreman