

From: Jane Cooper <Jane.Cooper@midsussex.gov.uk>
Sent: 21 April 2026 11:03:14 UTC+01:00
To: "Joanne Fisher" <Joanne.Fisher@midsussex.gov.uk>
Subject: DM/26/0833

Hi Jo,

I've looked at the acoustic report submitted and I'm not particularly concern however, for completeness, I would like to request the following details:

1. What are the proposed hours of use for the outside cocktail terrace.
2. Can the applicant confirm that the level of substation noise within neighbouring habitable rooms will not exceed the levels presented in table 1 of DEFRA report "Procedure for the assessment of low frequency noise complaints" NANR45: 2005.
3. Regarding the proposed lighting to this development, please can the applicant confirm that this will comply with guidance produced by the Institution of Lighting Professionals "The reduction of obtrusive light"

Thanks,

Jane Cooper
Environmental Health Officer
Environmental Health
Tel: +44 (0)1444 477437
Email: jane.cooper@midsussex.gov.uk
Website: www.midsussex.gov.uk



"Working together for a better Mid Sussex"