

From: Jane Cooper <Jane.Cooper@midsussex.gov.uk>
Sent: 27 August 2026 14:19:31 UTC+01:00
To: "Anna Tidey" <anna.tidey@midsussex.gov.uk>
Subject: DM/26/1999 Oakfield House

Hi Anna,

The applicant may need to submit an acoustic report, but if they provide the information outlined on page 13 of the Planning Noise Advice Document Sussex dated November 2023 this might suffice.

It's not clear from the information submitted which model of AC will be installed, also I need the sound pressure level at a specified distance (or the sound power level) which isn't given in the data. The model mentioned, ARXP20-35N9 RXP20-35N9, doesn't correspond with models listed on the specification table for RXP-N9.

Please can you let the applicant know.

Kind regards,

Jane Cooper
Environmental Health Officer
Environmental Health
Tel: +44 (0)1444 477437
Email: jane.cooper@midsussex.gov.uk
Website: www.midsussex.gov.uk



"Working together for a better Mid Sussex"