

From: planninginfo@midsussex.gov.uk <planninginfo@midsussex.gov.uk>
Sent: 17 April 2025 16:42:19 UTC+01:00
To: "planninginfo" <planninginfo@midsussex.gov.uk>
Subject: Mid Sussex DC - Online Register - Consultee Comments for Planning Application DM/25/0935

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 17/04/2025 4:42 PM from Mr Nick Bennett on behalf of Environmental Protection.

Application Summary

Reference:	DM/25/0935
Address:	Land Adjacent To Rowan East Of Turners Hill Road Crawley Down Crawley West Sussex RH10 3EP
Proposal:	Discharge of planning conditions C18 (External Lighting) and C23 (Electric Vehicle Charging) relating to planning reference DM/23/2961.
Case Officer:	Susan Dubberley

[Click for further information](#)

Comments Details

With regard to C18 (external lighting) it does not appear that the required details have been submitted/uploaded. Please can you clarify this? The condition states:

Comments:	Prior to the installation of any external lighting to the site, details of light intensity, spread and any shielding and times of use together with a report to demonstrate its effect on nearby residential properties shall be submitted to and approved in writing by the Local Planning Authority. It is recommended that the information be provided in a format that demonstrates compliance with the ILP Guidance Notes for the Reduction of Obtrusive Light. Relevant information is available from
-----------	--

the following site:
<https://www.theilp.org.uk/documents/obtrusive-light>. The lighting
concerned shall be
implemented in accordance with the approved details and
maintained as such
thereafter.

Kind regards